



By Appointment to
Her Majesty The Queen
Manufacturers of Fire Detection & Alarm Products
Apollo Fire Detectors Limited
Hampshire



Marine Equipment Directive 2014/90/EU

DECLARATION OF CONFORMITY

1. Unique identification code of the product-type:

Model number and Description:

58000-500MAR Ionisation Smoke Detector
55000-640 Optical Smoke Detector

Approved Accessories:

* Mounting bases are included in the Model number and Description section above.

2. This declaration of conformity is issued under the sole responsibility of the manufacturer:

3. Manufacturer Name and Address:

Apollo Fire Detectors Ltd
36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom

Authorised representative:

n/a

4. Object of the Declaration:

Commission Implementing Regulation (EU) 2019-1397

MED/3.51(d) – Smoke detectors

Model numbers and descriptions are included under section 1.

5. The object of the declaration above is in conformity with Directive 2014/90/EU

6. References to the relevant performance requirements and test standards:

(All products)

SOLAS 74 Reg. II-2/7
SOLAS 74 Reg. X/3
IMO Res.MSC.98(73)-(FSS Code) 9
IMO Res.MSC.97(73)-(2000 HSC Code) 7
IMO Res.MSC.36 (63)-(1994 HSC Code) 7
IMO Res.MSC.391 (95)-(IGF Code) 11
MSC.1?Circ.1242

IEC 60092-504:2016
IEC 60533:2015

(As applicable)

Fire detection and alarm systems

EN 54-7:2018 (Point detectors using scattered light, transmitted light or ionization)

A HALMA COMPANY



Assessed to ISO 9001:2015
Cert.LPCB ref: 010

Assessed to ISO 14001:2015
Cert.LPCB ref: 010 EMS

Cert.LPCB ref: 010

Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

Apollo Fire Detectors Ltd. Registered in England No. 1483208

Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 399 0553 54

7. **The notified body ABS Europe Limited (0729) performed a module B+D conformity assessment procedure and issued the certificate(s):**

Module D – 11-SO792467-15-MED (valid from 20 April 2020 until 09 March 2025)

Module B – 20-1986297-EC

8. **Additional Information – Application and / or limitations (if any), as specified in EC Type Examination Certificate (Module B or G):**

Ex-certification is not covered by this declaration nor by the certificates referenced in 7 above.

9. **Signature**

Signed for and on behalf of Apollo Fire Detectors Limited by



Mr. Karl Westhead
Technical Director

Place and Date of Issue: Havant – 19 May 2020

(v1)