



By Appointment to
Her Majesty The Queen
Manufacturers of Fire Detection & Alarm Products
Apollo Fire Detectors Limited
Hampshire



Marine Equipment Directive 2014/90/EU

DECLARATION OF CONFORMITY

1. **Unique identification code of the product-type:**

Model number and Description:

55000-773MAR XP95 Marine DIN Rail Zone Monitor Module

Approved Accessories:

* Mounting bases are included in the Model number and Description section above.

2. **This declaration of conformity is issued under the sole responsibility of the manufacturer:**

3. **Manufacturer Name and Address:**

Apollo Fire Detectors Ltd
36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom

4. **Authorised representative:**

Nora Gehner
Apollo Gesellschaft für Meldetechnologie mbH
Am Anger 31
33332 Gütersloh
Deutschland

Note that Apollo UK has, by issue of written mandate, authorised the above entity to act as Importer for these products and carry out the duties required of an Importer within the EU.

5. **Object of the Declaration:**

Commission Implementing Regulation (EU) 2020/1170

MED/3.51(h) – Input/Output Devices

Model numbers and descriptions are included under section 1.

6. **The object of the declaration above is in conformity with Directive 2014/90/EU**

7. **References to the relevant performance requirements and test standards:**

SOLAS 74 Reg. II-2/7
SOLAS 74 Reg. X/3
IMO Res.MSC.98(73)-(FSS Code) 9
IMO Res.MSC.36(63)-(1994 use Code) 7
IMO Res.MSC.97(73)-(2000 HSC Code) 7
IMO Res.MSC.391(95)-(IGF Code) 11
IMO MSC.1/Circ.1242
IEC 60092-504:2016
IEC 60533:2015

A HALMA COMPANY



Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK
t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

Apollo Fire Detectors Ltd. Registered in England No. 1483208
Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 339 0553 54

Fire detection and alarm systems

EN 54-18:2005 + A1(2007) – Input/Output Devices

8. **The notified body ABS ITALY S.R.L. (2843) performed a module B+D conformity assessment procedure and issued the certificate(s):**

Module D – 11-792467-18-MED (valid from 25 June 2021 until 16 April 2025)

Module B – 20-2018758-EC2

8. **Additional Information – Application and / or limitations (if any), as specified in EC Type Examination Certificate (Module B or G):**

Ex-certification is not covered by this declaration nor by the certificates referenced in 7 above.

9. **Signature**

Signed for and on behalf of Apollo Fire Detectors Limited by



Mr. Karl Westhead
Technical Director

Havant – 05 August 2021

(v2)

