



Construction Products Regulation: EU (No) 305/2011

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

DECLARATION OF PERFORMANCE

No. E0153

1. Unique identification code of the product-type:

Model number and Description:

45681-709 XP95 Visual Alarm Device Base (White) with Isolator

Approved Accessories:

45681-292 White Cap (Lockable) 45681-293 Red Cap (Lockable)

Harmonised Product Type(s):

Short-circuit isolators Visual Alarm Devices

2. Intended use/es:

Fire detection and fire alarm systems installed in and around buildings Fire safety

3. Manufacturer:

Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

4. Authorised representative:

Apollo Gesellschaft für Meldetechnologie mbH Am Anger 31 33332 Gütersloh Deutschland

5. System(s) of AVCP

System 1

6 Harmonised Standard(s)

EN 54-17:2005 EN54-23:2010

Notified Body/ies:

DBI Certification A/S (Notified Body 2531)

A HALMA COMPANY







Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

7. Declared performance

Essential Characteristics	Standard EN54-17:2005	Performance
Performance under fire conditions	5.2 1)	Pass
Operational reliability	4	Pass
Durability of operational reliability: temperature resistance	5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	5.8	Pass
Durability of operational reliability: electrical stability	5.3,5.13	Pass

¹⁾ This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices



Essential Characteristics	Standard EN54-23:2010	Performance
Operational reliability:		
Duration of operation	4.2.1	
Provision for external conductors	4.2.2	_
Flammability of materials	4.2.3	Pass
Enclosure protection	4.2.4	
Access	4.2.5	
Manufacturer's adjustments	4.2.6	
On-site adjustment of behaviour	4.2.7	
Requirements for software controlled devices	4.2.8	
Performance parameters under fire condition:		
Coverage volume	4.3.1	
Variation of light output	4.3.2	
Minimum and maximum light intensity	4.3.3	
Light colour	4.3.4	_
Light temporal pattern and frequency of	4.3.5	Pass
flashing		
Marking and data	4.3.6	
Synchronisation (option with	4.3.7	
requirements)		
Durability:		
Temperature resistance:	4.4.4	
Dry heat (optional)	4.4.1.1	
Dry heat (endurance)	4.4.1.2	
Cold (operational)	4.4.1.3	
Humidity Resistance:	4.4.2.1	
Damp heat, cyclic (operational) Damp heat, steady state (endurance)	4.4.2.1	
Damp heat, cyclic (endurance)	4.4.2.3	
Shock and vibration resistance:	4.4.2.3	Pass
Shock (operational)	4.4.3.1	
Impact (operational)	4.4.3.1	
Vibration (operational)	4.4.3.3	
Vibration (operational) Vibration (endurance)	4.4.3.4	
Corrosion resistance:	7.7.0.4	
SO ₂ corrosion (endurance)	4.4.4	
Electrical stability:	7.7. 7	
EMC, Immunity (operational)	4.4.5	
, ministry (spotational)		



8. Online Display Location

This document can be viewed online at www.apollo-fire.co.uk

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above

Signed for and on behalf of Apollo Fire Detectors Limited by:

Mr. David Robbins Technical Director Havant – 12.01.2023

(8v)

