



By Appointment to  
Her Majesty The Queen  
Manufacturers of Fire Detection & Alarm Products  
Apollo Fire Detectors Limited  
Hampshire



**Construction Products Regulation:  
EU (No) 305/2011**

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

**DECLARATION OF PERFORMANCE**

**No. E0087**

**1. Unique identification code of the product-type:**

**Model number and Description:**

ORB-HT-11004-APO Orbis Class BS Heat Detector with SensAlert and FasTest  
ORB-HT-11016-APO Orbis Class BS Heat Detector with Flashing LED, SensAlert and FasTest

**Approved Accessories:**

Bases: ORB-MB-00001-APO, ORB-MB-00002-APO, ORB-DB-00003-APO, ORB-RB-10004-APO, ORB-MB-00012-APO, ORB-MB-00019-APO

Ancillary: ORB-BA-10008-APO Adaptor Base (to be used in conjunction with the following bases only 45681-200, 45681-201)

**Harmonised Product Type(s):**

Heat Detectors – Point Detectors

**2. Intended use/es:**

Point detectors for use in fire detection and fire alarm systems installed in and around buildings

**3. Manufacturer:**

Apollo Fire Detectors Ltd,  
36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

**4. Authorised representative:**

Apollo Gesellschaft für Meldetechnologie mbH  
Am Anger 31  
33332 Gütersloh  
Deutschland

**5. System of AVCP**

System 1

**6a. Harmonised Standard(s)**

EN 54-5:2017 + A1:2018

**6b. Notified Body:**

DBI Certification A/S (Notified Body 2531)

A HALMA COMPANY



**Apollo Fire Detectors Limited**

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK  
t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

[www.apollo-fire.co.uk](http://www.apollo-fire.co.uk)

Apollo Fire Detectors Ltd. Registered in England No. 1483208  
Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 339 0553 54

## 7. Declared performance

**Table 1**

Detector Category (Heat Class):	Typical Application Temperature	Maximum Application Temperature °C	Minimum Static Response Temperature °C	Maximum Static Response Temperature °C
BS	40	65	69	85

**Table 2- Response time limits**

Rate of rise of air temperature K min-1	Cat BS			
	Lower limit		Upper limit	
	Min	S	Min	S
1	29	0	46	0
3	7	13	16	0
5	4	9	10	0
10	2	0	5	30
20	1	30	3	13
30		40	2	25

### Performance

Essential characteristics	Clauses in EN 54-5:2017/ A1:2018	Regulatory classes	Performance
<b>Operational reliability:</b>			
Position of heat sensitive element	4.2.1	BS	The heat sensitive element(s) or at least part of it, except elements with auxiliary functions (e.g. characteristic correctors), are a distance $\geq 15$ mm from the mounting surface of the point heat detector.
Individual alarm indication	4.2.2		Category BS The heat detector is provided with an integral red visual indicator and can remain identified until the alarm is reset. The visual indicator is visible from a distance of 6 m directly below the point heat detector, in an ambient light intensity up to 500 lx.
Connection of ancillary devices	4.2.3		Open or short circuit failures of connection to ancillary device do not prevent the correct operation of the detector
Monitoring of detachable point heat detectors	4.2.4		A fault condition is signaled when the detector is removed from the mounting base.
Manufacturer's adjustments	4.2.5		It is not possible to change the manufacture's settings except by special means (e.g. a special code or tool, or by breaking or remove a seal).

Onsite adjustments of response behavior	4.2.6	N/A																				
Software controlled detectors (when provided)	4.2.7	The software documentation and the software design complies supplied by the manufacturer with the requirements of this standard.																				
<b>Nominal activation conditions/Sensitivity:</b>																						
Directional dependence	4.3.1	The response time of the point detector do not unduly depend on the direction of airflow around the point heat detector.																				
Static response temperature	4.3.2	The response temperatures of the point heat detectors lie between the minimum and maximum static response temperatures, according to the category of the point heat detector in Table 1 above.																				
Response times from typical application temperature	4.3.3	The response times of the point heat detector lie between the lower and upper response time limits for the appropriate point heat detector category in Table 2 above.																				
Response times from 25 °C	4.3.4	The response time at 3 K min <sup>-1</sup> exceeds 7 min 13 s and the response time at 20 K min <sup>-1</sup> exceeds 1 min 0 s.																				
Response times from high ambient temperature	4.3.5	No alarm or fault signal was given at high ambient temperatures appropriate to the anticipated service temperatures.  BS 3 K min <sup>-1</sup> , Lower limit, 1 min 20 s and upper limit 16 m. 20 K min <sup>-1</sup> , Lower limit, 12 s and upper limit 3 m 13 s.																				
Reproducibility	4.3.6	The response times of the point heat detectors lie between the lower ad upper response time limits specified in Table 2 above.																				
<b>Response delay (response time):</b>																						
Additional test for suffix S point heat detectors	4.4.1	Suffix S point heat detector did not exceed the lower limits of response time during the transfer period or during the 10 min exposure below.  <table border="1" data-bbox="774 1444 1289 1617"> <thead> <tr> <th>Point heat detector category</th> <th>Conditioning Temperature °C</th> <th>Airflow Temperature °C</th> </tr> </thead> <tbody> <tr> <td>BS</td> <td>20 ±2</td> <td>65 ±2</td> </tr> </tbody> </table>  <table border="1" data-bbox="774 1646 1337 1944"> <thead> <tr> <th rowspan="2">Rate of rise of air temperature K min<sup>-1</sup></th> <th colspan="2">Lower Limit response time</th> </tr> <tr> <th>Min</th> <th>S</th> </tr> </thead> <tbody> <tr> <td>3</td> <td>9</td> <td>40</td> </tr> <tr> <td>5</td> <td>5</td> <td>48</td> </tr> <tr> <td>10</td> <td>2</td> <td>54</td> </tr> </tbody> </table>	Point heat detector category	Conditioning Temperature °C	Airflow Temperature °C	BS	20 ±2	65 ±2	Rate of rise of air temperature K min <sup>-1</sup>	Lower Limit response time		Min	S	3	9	40	5	5	48	10	2	54
Point heat detector category	Conditioning Temperature °C	Airflow Temperature °C																				
BS	20 ±2	65 ±2																				
Rate of rise of air temperature K min <sup>-1</sup>	Lower Limit response time																					
	Min	S																				
3	9	40																				
5	5	48																				
10	2	54																				

			20	1	27
			30		58
Additional test for suffix R point heat detectors	4.4.2		N/A		
<b>Tolerance to supply voltage:</b>					
Variation in supply parameters	4.5		The point heat detector does not unduly depend on variation in the supply parameters and lie between the lower and upper response time limits specified in Table 2 above.		
<b>Durability of nominal activation conditions/Sensitivity:</b>					
temperature resistance					
Cold (operational)	4.6.1.1		<p>No alarm or fault signal was given during the transition to the conditioning temperature or during the period at the condition temperature</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>BS: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>		
Dry heat (endurance)	4.6.1.2		<p>No fault signal was given on reconnection attributable to the endurance conditioning</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>BS: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>		
Humidity resistance					
Damp heat, cyclic (operational)	4.6.2.1		<p>No alarm or fault signal was given during the conditioning.</p> <p>Lower temperature: (25±3) °C Upper temperature: (40±2) °C</p> <p>Relative humidity: At lower temperature : ≥ 95 % At upper temperature : (93 ±3) %</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>BS: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>		
Damp heat, steady-state (endurance)	4.6.2.2		<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning</p>		

		<p>Temperature : 40 ±2 °C  Relative Humidity: 93 ±3 %  Duration : 21 days</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>BS: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Corrosion resistance		
Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	4.6.3	<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning  Temperature : 25 ±2 °C  Relative Humidity: 93 ±3 %  SO<sub>2</sub> concentration: 25 ±5 ppm (by volume)  Duration : 21 days</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>BS: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Vibration resistance		
Shock (operational)	4.6.4.1	<p>No alarm or fault signal was given during the conditioning period or an additional 2 min.</p> <p>For specimen with a mass ≤ 4,75 kg :</p> <p>Shock pulse type: Half sine  Pulse duration : 6 ms  Peak acceleration: 10X (100-20M) ms<sup>-2</sup> (M is specimen mass in Kg)  Number of directions: 6  Pulses per direction: 3</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>BS: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Impact (operational)	4.6.4.2	<p>No alarm or fault signal was given during the conditioning period or an additional 2 min.</p> <p>Conditioning:  Impact energy: 1,9 ±0,1 J  Hammer velocity: 1,5 ±0,13 ms<sup>-1</sup>  Number of impacts: 1</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p>

			BS: 20 K min <sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6
Vibration, sinusoidal (operational)	4.6.4.3		<p>No fault signal was given during the conditioning</p> <p>Conditioning:  Frequency range: 10 to 150 Hz  Acceleration amplitude: 5 ms<sup>-2</sup>(≈0,5 g<sub>n</sub>)  Number of axes : 3  Sweep rate: 1 octave min<sup>-1</sup>  Number of sweep cycles: 1 per axis</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>BS: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Vibration, sinusoidal (endurance)	4.6.4.4		<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning:  Frequency range: 10 to 150 Hz  Acceleration amplitude: 10 ms<sup>-2</sup>(≈1,0 g<sub>n</sub>)  Number of axes : 3  Sweep rate: 1 octave min<sup>-1</sup>  Number of sweep cycles: 20 per axis</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>BS: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Electrical stability EMC immunity (operational)	4.6.5		<p>Compliance in EN 50130-4:2011 and No fault signal was given during the conditioning.</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>BS: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>

## 8. Online Display Location

This document can be viewed online at [www.apollo-fire.co.uk](http://www.apollo-fire.co.uk)

The performance of the product identified above is in the conformity with the set of declared performance/s.  
This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above

Signed for and on behalf of Apollo Fire Detectors Limited by:

A handwritten signature in blue ink, appearing to be 'D. Robbins', written over a horizontal line.

Mr. David Robbins  
Technical Director  
Havant – 05.07.2022

(v5)