



# Construction Products Regulation: EU (No) 305/2011

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

#### **DECLARATION OF PERFORMANCE**

No. E0090

#### 1. Unique identification code of the product-type:

## **Model number and Description:**

ORB-HT-11166 Orbis Class A1S Heat Detector with SensAlert and FasTest ORB-HT-11167 Orbis Class A1S Heat Detector with Flashing LED, SensAlert and FasTest

#### **Approved Accessories:**

Bases: ORB-MB-00001-APO,ORB-MB-00002-APO,ORB-DB-00003-APO,ORB-RB-10004-APO,ORB-MB-00012-APO,ORB-MB-00019-APO

Ancillary: ORB-BA-10008-APO Adaptor Base (to be used in conjunction with the following bases only 45681-200,45681-201)

## Harmonised Product Type(s):

Heat Detectors - Point Detectors

#### 2. Intended use/es:

Point detectors for use in fire detection and fire alarm systems installed in and around buildings

#### 3. Manufacturer:

Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

## 4. Authorised representative:

Apollo Gesellschaft für Meldetechnologie mbH Am Anger 31 33332 Gütersloh Deutschland

## 5. System of AVCP

System 1

#### 6a. Harmonised Standard(s)

EN 54-5:2017 + A1:2018

# 6b. Notified Body:

DBI Certification A/S (Notified Body 2531)

A HALMA COMPANY







**Apollo Fire Detectors Limited** 

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

## 7. Declared performance

Table 1				
Detector Category (Heat Class):	Typical Application Temperature	Maximum Application Temperature °C	Minimum Static Response Temperature °C	Maximum Static Response Temperature °C
A1S	25	50	54	65

# Table 2- Response time limits

Rate of rise of air temperature	Cat A1S					
K min-1	Lower limit		Uper limit			
	Min	S	Min	S		
1	29	0	40	20		
3	7	13	13	40		
5	4	9	8	20		
10	1	0	4	20		
20		30	2	20		
30		20	1	40		

## Performance

Essential characteristics	Clauses in EN 54-5:2017/ A1:2018	Regulatory classes	Performance
Operational reliability:			
Position of heat sensitive element	4.2.1		The heat sensitive element(s) or at least part of it, except elements with auxiliary functions (e.g.characteristic correctors), are a distance ≥15mm from the mounting surface of the point heat detector.
Individual alarm indication	4.2.2	A1S	Category A1S The heat detector is provided with an integral red visual indicator and can remain identified until the alarm is reset. The visual indicator is visible from a distance of 6 m directly below the point heat detector, in an ambient light intensity up to 500 lx.
Connection of ancillary devices	4.2.3	_	Open or short circuit failures of connection to ancillary device do not prevent the correct operation of the detector
Monitoring of detachable point heat detectors	4.2.4	_	A fault condition is signaled when the detector is removed from the mounting base.
Manufacturer's adjustments	4.2.5		It is not possible to change the maufacture's settings expept by special means (e.g. a special code or tool, or by breaking or remove a seal).



0 : 1:	126	N/A				
Onsite adjustments of	4.2.6	N/A				
response behavior						
Software controlled 4.2.7		The software documentation and the software design				
detectors (when provided)		complies supplied by the manufacturer with the				
		requirements of this standard.				
Nominal activation						
conditions/Sensitivity:						
Directional dependence	4.3.1	The response time of the point dectetor do not unduly				
Bir cetional dependence	1.5.1	depend on the direction of airflow around the point				
		heat detector.				
		neat detector.				
6	422					
Static response	4.3.2	The response temperatures of the point heat detectors lie				
temperature		between the minimum and maximum static response				
		temperatures, according to the category of the point hear				
		detector in Table 1 above.				
Response times from	4.3.3	The response times of the point heat detector lie				
typical application		between the lower and upper response time limits for				
temperature		the appropriate point heat detector category in Table 2				
temperature						
		above.				
Response times from 25 °C	4.3.4	The response time at 3 K min <sup>-1</sup> exceeds 7 min 13 s and the				
		response time at 20 K min <sup>-1</sup> exceeds 1 min 0 s.				
Response times from high	4.3.5	No alarm or fault signal was given at high ambient				
ambient temperature		temperatures appropriate to the anticipated service				
		temepratures.				
		temeprotories.				
		A1S				
		3 K min <sup>-1</sup> , Lower limit, 1 min 20s and upper limit 13 m 40s				
		20 K min <sup>-1</sup> , Lower limit, 12 s and upper limit 2 m 20 s.				
Reproducibility	4.3.6	The response times of the point heat detectors lie				
		between the lower ad upper response time limits				
		specified in Table 2 above.				
Response delay (response						
time):						
Additional test for suffix S	4.4.1	Suffix S point heat detector did not exceed the lower				
point heat detectors	7.7.1	limits of response time during the transer period or				
point neat detectors		during the 10 min exposure below.				
		during the 10 min exposure below.				
		Point heat   Conditioning   Airflow				
		detector Temperature °C Temperature °C				
		category				
		A1S 5 ±2 50 ±2				
		Rate of rise of air Lower Limit response				
		temperature K min <sup>-1</sup> time				
		Min S				
		3 9 40				
		5 5 48				
1						
		10 2 54				



			20	1		27
			30			58
Additional test for suffix R point heat detectors	4.4.2					
Tolerance to supply voltage:						
Variation in supply parameters	4.5		The point heat detector does not unduly depent on variation in the supply parameters and lie between the lower and upper response time limits specified in Table 2 above.			
Durability of nominal activation conditions/Sensitivity:						
Temperature resistance						
Cold (operational)	4.6.1.1		No alarm or fault signal was given during the transition to the conditioning temperature or during the period at the condition temperature			
			Response time at 3 K and did not exceed 2 obtained in 4.3.6.			
			A1S: 20 K min <sup>-1</sup> was n 30 s compared with the			
Dry heat (endurance)	4.6.1.2		No fault signal was given the endurance conditions to the conditions of the conditio		connection a	ttributable to
			Response time at 3 K and did not exceed 2 obtained in 4.3.6.			
			A1S: 20 K min <sup>-1</sup> was n 30 s compared with th			
Humidity resistance						
Damp heat, cyclic (operational)	4.6.2.1		No alarm or fault sign conditioning.	nal was giv	ven during th	ie
			Lower temperature: ( Upper temperature: (			
			Relative humidity: At lower temperature At upper temperature		) %	
			Response time at 3 K and did not exceed 2 obtained in 4.3.6.			
			A1S: 20 K min <sup>-1</sup> was n 30 s compared with t			
Damp heat, steady-state (endurance)	4.6.2.2		No fault signal was gir the endurance condit		connection a	ttributable to
			Conditioning			X



		Temperature: 40 ±2 °C Relative Humidity: 93 ±3 % Duration: 21 days
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.
		A1S: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
Corrosion resistance Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	4.6.3	No fault signal was given on reconnection attributable to the endurance conditioning.
		Conditioning Temperature: 25 ±2 °C Relative Humidity: 93 ±3 % SO2 concentration: 25 ±5 ppm (by volume) Duration: 21 days
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.
		A1S: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
Vibration resistance		
Shock (operational)	4.6.4.1	No alarm or fault signal was given during the conditioning period or an additional 2 min.
		For specimen with a mass ≤ 4,75 kg:
		Shock pulse type: Half sine Pulse duration: 6 ms
		Peak acceleration: 10X (100-20M) ms-2 (M is specimen mass in Kg) Number of directions: 6
		Pulses per direction: 3
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.
		A1S: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
Impact (operational)	4.6.4.2	No alarm or fault signal was given during the conditioning period or an additional 2 min.
		Conditioning: Impact energy: 1,9 ±0,1 J Hammer velocity: 1,5 ±0,13 ms <sup>-1</sup> Number of impacts: 1
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.



		A1S: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed
		30 s compared with the time obtained in 4.3.6
Vibration, sinusoidal	4.6.4.3	No fault signal was given during the conditioning
(operational)		Conditioning:
		Frequency range: 10 to 150 Hz
		Acceleration amplitude: 5 ms <sup>-2</sup> (≈0,5 g <sub>n</sub> )
		Number of axes : 3
		Sweep rate: 1 octave min <sup>-1</sup>
		Number of sweep cycles: 1 per axis
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s
		and did not exceed 2 min 40 s compared with the time
		obtained in 4.3.6.
		A1S: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed
		30 s compared with the time obtained in 4.3.6
Vibration, sinusoidal	4.6.4.4	No fault signal was given on reconnection attributable to
(endurance)		the endurance conditioning.
		Conditioning:
		Frequency range: 10 to 150 Hz
		Acceleration amplitude: 10 ms <sup>-2</sup> (≈1,0 g <sub>n</sub> )
		Number of axes : 3
		Sweep rate: 1 octave min <sup>-1</sup>
		Number of sweep cycles: 20 per axis
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s
		and did not exceed 2 min 40 s compared with the time
		obtained in 4.3.6.
		A1S: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed
		30 s compared with the time obtained in 4.3.6
Electrical stability EMC	4.6.5	Compliance in EN 50130-4:2011 and No fault signal was
immunity (operational)		given during the conditioning.
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s
		and did not exceed 2 min 40 s compared with the time
		obtained in 4.3.6.
		A1S: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed
		30 s compared with the time obtained in 4.3.6
<u>l</u>	1	



## 8. Online Display Location

This document can be viewed online at www.apollo-fire.co.uk

The performance of the product identified above is in the conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above

Signed for and on behalf of Apollo Fire Detectors Limited by:

Mr. David Robbins Technical Director

Havant -05.07.2022

(v5)

