



#### Construction Products Regulation: EU (No) 305/2011

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

# **DECLARATION OF PERFORMANCE**

### No. E0038

## 1. Unique identification code of the product-type:

### Model number and Description:

ORB-HT-51145 Orbis Intrinsically Safe Class A1R Heat Detector with SensAlert/FasTestVariant: ORB-HT-51146 Orbis Intrinsically Safe Class A1R Heat Detector with Flashing LED/SensAlert/FasTest

### **Approved Accessories:**

Base: ORB-MB-50018, ORB-BA-50008, 45681-207

### Harmonised Product Type(s):

Heat Detectors - Point Detectors

### 2. Intended use/es:

Point detectors for use in fire detection and fire alarm systems installed in and around buildings

#### 3. Manufacturer:

Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

## 4. Authorised representative:

Apollo Gesellschaft für Meldetechnologie mbH Am Anger 31 33332 Gütersloh Deutschland

# 5. System of AVCP

System 1

6a. Harmonised Standard(s)

EN 54-5:2017 + A1:2018

6b. Notified Body:

DBI Certification A/S (Notified Body 2531)

# A HALMA COMPANY



Apollo Fire Detectors Limited 36 Brookside Road, Havant, Hampshire, PO9 1JR, UK t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

Apollo Fire Detectors Ltd. Registered in England No. 1483208 Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 339 0553 54

# 7. Declared performance

Table 1				
Detector Category (Heat Class):	Typical Application Temperature	Maximum Application Temperature °C	Minimum Static Response Temperature °C	Maximum Static Response Temperature °C
A1R	25	50	54	65

# Table 2- Response time limits

Rate of rise of air temperature K min-1	Cat Lower limit		: A1R Uper limit	
	Min	S	Min	S
1	29	0	40	20
3	7	13	13	40
5	4	9	8	20
10	1	0	4	20
20		30	2	20
30		20	1	40

# Performance

Essential characteristics	Clauses in EN 54-5:2017/ A1:2018	Regulatory classes	Performance
Operational reliability:			
Position of heat sensitive element	4.2.1		The heat sensitive element(s) or at least part of it, except elements with auxiliary functions (e.g.characteristic correctors), are a distance ≥15mm from the mounting surface of the point heat detector.
Individual alarm indication	4.2.2	A1R	Category A1R The heat detector is provided with an integral red visual indicator and can remain identified until the alarm is reset. The visual indicator is visible from a distance of 6 m directly below the point heat detector, in an ambient light intensity up to 500 lx.
Connection of ancillary devices	4.2.3	-	Open or short circuit failures of connection to ancillary device do not prevent the correct operation of the detector
Monitoring of detachable point heat detectors	4.2.4	-	A fault condition is signaled when the detector is removed from the mounting base.
Manufacturer's adjustments	4.2.5		It is not possible to change the maufacture's settings expept by special means (e.g. a special code or tool, or by breaking or remove a seal).



Onsite adjustments of	4.2.6	N/A
response behavior		
Software controlled	4.2.7	The software documentation and the software design
detectors (when provided)		complies supplied by the manufacturer with the
		requirements of this standard.
Nominal activation		
conditions/Sensitivity:		
Directional dependence	4.3.1	The response time of the point dectetor do not unduly
		depend on the direction of airflow around the point
		heat detector.
Statia raspansa	4 2 2	The regrance temperatures of the point heat detectors lie
temperature	4.5.2	hetween the minimum and maximum static response
temperature		temperatures according to the category of the point heat
		detector in Table 1 above.
Response times from	4.3.3	The response times of the point heat detector lie
typical application		between the lower and upper response time limits for
temperature		the appropriate point heat detector category in Table 2
		above.
Response times from 25 °C	4.3.4	The response time at 3 K min <sup>-1</sup> exceeds 7 min 13 s and the
		response time at 20 K min <sup>-1</sup> exceeds 1 min 0 s.
Response times from high	4.3.5	No alarm or fault signal was given at high ambient
ambient temperature		temperatures appropriate to the anticipated service
		temepratures.
		Δ1R
		3 K min <sup>-1</sup> . Lower limit, 1 min 20s and upper limit 13 m 40s.
		20 K min <sup>-1</sup> , Lower limit, 12 s and upper limit 2 m 20 s.
Reproducibility	4.3.6	The response times of the point heat detectors lie
		between the lower ad upper response time limits
		specified in Table 2 above.
Response delay (response		
time):		
Additional test for suffix S	4.4.1	N/A
point heat detectors		
Additional test for suffix R	4.4.2	Suffix R, the point heat detector maintains the
point heat detectors		response requirements of its category, in table 2
		above, for high rates of rise of temperature from an
		temperature applicable to the category marked on it
		Point heat detector Initial conditioning
		category temperature °C
		A1R 5 ±2
Tolerance to supply		
voltage:		
Variation in supply	4.5	The point heat detector does not unduly depent on
parameters		variation in the supply parameters and lie between the
		iower and upper response time limits specified in Table 2



Durability of nominal		
activation		
conditions/Sensitivity:		
temperature resistance		
Cold (operational)	4.6.1.1	No alarm or fault signal was given during the transition to the conditioning temperature or during the period at the condition temperature
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.
		A1R: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
Dry heat (endurance)	4.6.1.2	No fault signal was given on reconnection attributable to the endurance conditioning
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.
		A1R: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
Humidity resistance		
Damp heat, cyclic	4.6.2.1	No alarm or fault signal was given during the
(operational)		conditioning.
		Lower temperature: (25±3) °C Upper temperature: (40±2) °C
		Relative humidity:
		At lower temperature : $\geq 95\%$
		At upper temperature : (93 ±3) %
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.
		A1D: 20 K minil was not loss than 20 s, and did not average
		30 s compared with the time obtained in 4.3.6
Damp heat, steady-state (endurance)	4.6.2.2	No fault signal was given on reconnection attributable to the endurance conditioning.
		Conditioning
		Temperature : 40 ±2 °C
		Relative Humidity: 93 ±3 %
		Duration : 21 days
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.
		A1R: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
Corrosion resistance		
Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	4.6.3	No fault signal was given on reconnection attributable to the endurance conditioning.



		Conditioning
		Tomporature : $25 \pm 2$ °C
		$\frac{1}{1000} = \frac{1}{1000} = 1$
		Relative Humanity: $93 \pm 3\%$
		SO2 concentration: 25 ±5 ppm (by volume)
		Duration : 21 days
		Been ence there at 2 K whether we there there 7 whether 42 a
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s
		and did not exceed 2 min 40 s compared with the time
		obtained in 4.3.6.
		A1R: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed
		30 s compared with the time obtained in 4.3.6
Vibration resistance		
Shock (operational)	4.6.4.1	No alarm or fault signal was given during the
		conditioning period or an additional 2 min.
		For specimen with a mass $\leq$ 4,75 kg :
		Shock pulse type: Half sine
		Pulse duration: 6 ms
		Peak acceleration: 10X (100-20M) ms-2 (M is specimen
		mass in Kg)
		Number of directions: 6
		Pulses per direction: 3
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s
		and did not exceed 2 min 40 s compared with the time
		obtained in 4.3.6
		A1B: 20 K min <sup>-1</sup> was not less than 30 s, and did not exceed
		AIR. 20 K mill was not less than 50 s and did not exceed
		So's compared with the time obtained in 4.5.6
Impact (operational)	4642	No alarm or fault signal was given during the
inipact (operational)	4.0.4.2	No diality of radic signal was given during the
		conditioning period of an additional 2 min.
		Conditioning
		Impact on organ 1.0 ±0.1 L
		Human and a site 1,5 ±0,1 J
		Hammer velocity: 1,5 ±0,13 ms <sup>-1</sup>
		Number of Impacts: 1
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s
		and did not exceed 2 min 40 s compared with the time
		obtained in 4.3.6.
		A1R: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed
		30 s compared with the time obtained in 4.3.6
Vibration, sinusoidal	4.6.4.3	No fault signal was given during the conditioning
(operational)		Conditioning:
		Frequency range: 10 to 150 Hz
		Acceleration amplitude: 5 ms <sup>-2</sup> (≈0,5 g <sub>n</sub> )
		Number of axes : 3
		Sweep rate: 1 octave min <sup>-1</sup>
		Number of sweep cycles: 1 per axis
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s
		and did not exceed 2 min 40 s compared with the time
		obtained in 4.3.6.
		A1R: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed
		30  s compared with the time obtained in 4.3.6



Vibration, sinusoidal (endurance)	4.6.4.4	No fault signal was given on reconnection attributable to the endurance conditioning.
		Conditioning:
		Frequency range: 10 to 150 Hz
		Acceleration amplitude: 10 ms <sup>-2</sup> ( $\approx$ 1,0 g <sub>n</sub> )
		Number of axes : 3
		Sweep rate: 1 octave min <sup>-1</sup>
		Number of sweep cycles: 20 per axis
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.
		A1R: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
Electrical stability EMC immunity (operational)	4.6.5	Compliance in EN 50130-4:2011 and No fault signal was given during the conditioning.
		Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s
		and did not exceed 2 min 40 s compared with the time
		obtained in 4.3.6.
		A1R: 20 K min <sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
	1	

# 8. Online Display Location

This document can be viewed online at www.apollo-fire.co.uk

The performance of the product identified above is in the conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above

Signed for and on behalf of Apollo Fire Detectors Limited by:

Mr. David Robbins Technical Director

Havant - 05.07.2022 (v8)

