



By Appointment to
Her Majesty The Queen
Manufacturers of Fire Detection & Alarm Products
Apollo Fire Detectors Limited
Hampshire



**Construction Products Regulation:
EU (No) 305/2011**

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

DECLARATION OF PERFORMANCE

No. 0832-CPR-F0089

1. Unique identification code of the product-type:

Model number and Description:

45681-284 XP95/Discovery Short Circuit Isolating Base

45681-284LIM XP95/Discovery Short Circuit Isolating Base

Approved Accessories:

n/a

Harmonised Product Type(s):

Short-circuit isolators

2. Intended use/es:

Fire detection and fire alarm systems

3. Manufacturer:

Apollo Fire Detectors Ltd,
36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

4. Authorised representative:

n/a

5. System of AVCP

System 1

6a. Harmonised Standard(s)

EN 54-17:2005

6b. Notified Body:

BRE Global Limited (Notified Body 0832)

A HALMA COMPANY



Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK
t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

Apollo Fire Detectors Ltd. Registered in England No. 1483208
Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 339 0553 54

7. Declared performance

Essential Characteristics	Standard EN54-17:2005	Performance
Performance under fire conditions	5.2 1)	Pass
Operational reliability	4	Pass
Durability of operational reliability: temperature resistance	5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	5.8	Pass
Durability of operational reliability: electrical stability	5.3,5.13	Pass
1) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices		

The performance of the product identified above is in the conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above.

8. Online Display Location

This document can be viewed online at www.apollo-fire.co.uk

Signed for and on behalf of Apollo Fire Detectors Limited by:


pp.

Mr. Karl Westhead
Technical Director

Place and Date of Issue: Havant - 12 September 2019

(v2)

