



# Construction Products Regulation: 305/2011

#### **DECLARATION OF PERFORMANCE**

No. 0832-CPR-F2009

1. Unique identification code of the product-type:

#### 55000-017

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

### 55000-017 AlarmSense Open Area Sounder Visual Indicator

Each individual product is identified with a label containing a production date code with build standard number

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

## Fire detection and fire alarm systems

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

#### Texecom Ltd Bradwood Court, St Crispin Way, Haslingden, Lancashire BB4 4PW

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

#### Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, Hampshire, PO9 1JR

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

#### System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

BRE Global Limited (Notified Body 0832) has performed type testing of the product, initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and evaluation of factory production control under system 1 and issued the following Certificate of Constancy of Performance:

#### 0832-CPR-F2009

3. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable

(v1)





Assessed to ISO 9001:2008 LPCB Cert No. 010





**Apollo Fire Detectors Limited** 

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK t +44 (0)23 9249 2412 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

# 9. Declared performance

| Essential Characteristics   | Standard<br>EN54-3:2001 + A1:2002 +<br>A2:2006 | Performance |
|---|--|-------------|
| Performance under fire condition                                      | 4.2, 4.3, 5.2, 5.3                             | Pass        |
| Operational reliability   | 4.4, 4.5, 4.6, 5.4, C4                         | Pass        |
| Durability of operational reliability: temperature resistance         | 5.5, 5.6, 5.7, 5.8, 5.9                        | Pass        |
| Durability of operational reliability:<br>humidity resistance         | 5.8, 5.9, 5.10                                 | Pass        |
| Durability of operational reliability: corrosion resistance           | 5.11   | Pass        |
| Durability of operational reliability: shock and vibration resistance | 5.12 to 5.15                                   | Pass        |
| Durability of operational reliability:<br>electrical stability        | 5.16   | Pass        |
| Durability of operational reliability:<br>resistance to ingress       | 5.17   | Pass        |

<sup>5.6</sup> and 5.10 applies only to outdoor sounders or outdoor voice sounders.

The performance of the product identified above is in conformity with the performance and essential characteristics declared within this certificate. The declaration of performance is issued under the sole responsibility of Apollo Fire Detectors Limited.

Signed for and on behalf of Apollo Fire Detectors Limited by:

Mr. Karl Westhead Technical Director

K. Wester

Place and Date of Issue: Havant - 09 March 2017



<sup>5.16</sup> applies only to sounders or voice sounders with active electronic components.