



Construction Products Regulation: 305/2011

DECLARATION OF PERFORMANCE

No 0832-CPR-1539

1. Unique identification code of the product-type:

FL5100-600

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

FL5100-600 Soteria Dimension Optical Detector To be used in conjunction with Ancillary: FL5000-200 Soteria Dimension Back box

Each individual product is identified with a label containing a production date code with build standard number

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems

 Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, Hampshire, PO9 1JR

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, Hampshire, PO9 1JR

System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

BRE Global Limited (Notified Body 0832) has performed type testing of the product, initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and evaluation of factory production control under system 1 and issued the following Certificate of Constancy of Performance:

0832-CPR-1539

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable

[v1]

A HALMA COMPANY







Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR, UK
t +44 (0)23 9249 2412 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

9. Declared performance

Essential Characteristics	Standard EN54-7:2000 + A1:2002 + A2:2006	Performance	
Nominal activation conditions/Sensitivity. Response delay (response time) and Performance under fire conditions	4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18	Pass	
Operational reliability	4.2 to 4.7, 4.9 to 4.11	Pass	
Tolerance to supply voltage	5.5	Pass	
Durability of operational reliability and response delay: temperature resistance	5.8, 5.9	Pass	
Durability of operational reliability: vibration resistance	5.13 to 5.16	Pass	
Durability of operational reliability: humidity resistance	5.10,5.11	Pass	
Durability of operational reliability: corrosion resistance	5.12	Pass	
Durability of operational reliability: electrical resistance	5.17	Pass	

Essential Characteristics	Standard EN54-17:2005	Performance	
Performance under fire conditions	5.2	Pass	
Operational reliability	4	Pass Pass Pass Pass	
Durability of operational reliability: temperature resistance	5.4, 5.5		
Durability of operational reliability: vibration resistance	5.9 to 5.12		
Durability of operational reliability: humidity resistance	5.6, 5.7		
Durability of operational reliability: corrosion resistance	5.8		
Durability of operational reliability: electrical stability	5.3,5.13	Pass	

¹⁾ This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices



The performance of the product identified above is in conformity with the performance and essential characteristics declared within this certificate. The declaration of performance is issued under the sole responsibility of Apollo Fire Detectors Limited.

Signed for and on behalf of Apollo Fire Detectors Limited by:

Mr. Karl Westhead Technical Director

Place and Date of Issue: Havant - 18 May 2017

K. West

