

**Construction Products Regulation:
305/2011**

DECLARATION OF PERFORMANCE

No. 0832-CPR-F1318

1. Unique identification code of the product-type:

**SA4700-103
Variant:
SA4700-403**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

**SA4700-103 Intelligent Mains Switching Input/Output Unit
Variant:
SA4700-403 Intelligent DIN-Rail Mains Switching Input/Output Unit**

**To be used in conjunction with the following Ancillaries:
45681-400 Intelligent Interface Backbox
38532-092 Interface Small DIN Tub**

Each individual product is identified with a label containing a production date code with build standard number

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**Apollo Fire Detectors Ltd,
36 Brookside Road, Havant, Hampshire, PO9 1JR**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**Apollo Fire Detectors Ltd,
36 Brookside Road, Havant, Hampshire, PO9 1JR**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

BRE Global Limited (Notified Body 0832) has performed type testing of the product, initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and evaluation of factory production control under system 1 and issued the following Certificate of Constancy of Performance:

0832-CPR-F1318

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable

[v3]

A HALMA COMPANY



Assessed to ISO 9001:2008
LPCB Cert No. 010



Certificate No. 010
See www.RedBookLive.com



Assessed to ISO 14001:2004
Certificate number EMS 010

Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK
t +44 (0)23 9249 2412 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

Apollo Fire Detectors Ltd. Registered in England No. 1483208
Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB339 055354

9. Declared performance

| Essential Characteristics | Standard EN54-17:2005 | Performance |
|---|----------------------------------|--------------------|
| Performance under fire conditions | 5.2 1) | Pass |
| Operational reliability | 4 | Pass |
| Durability of operational reliability: temperature resistance | 5.4, 5.5 | Pass |
| Durability of operational reliability: vibration resistance | 5.9 to 5.12 | Pass |
| Durability of operational reliability: humidity resistance | 5.6, 5.7 | Pass |
| Durability of operational reliability: corrosion resistance | 5.8 | Pass |
| Durability of operational reliability: electrical stability | 5.3,5.13 | Pass |
| 1) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices | | |

| Essential Characteristics | Standard EN54-18:2005 | Performance |
|---|----------------------------------|--------------------|
| Performance delay (response time) | 5.2 1) | Pass |
| Performance under fire conditions | 5.1.4 | Pass |
| Operational reliability | 5.1.4 | Pass |
| Durability of operational reliability: temperature resistance | 5.3, 5.4 | Pass |
| Durability of operational reliability: vibration resistance | 5.8 to 5.11 | Pass |
| Durability of operational reliability: humidity resistance | 5.5, 5.6 | Pass |
| Durability of operational reliability: corrosion resistance | 5.7 | Pass |
| Durability of operational reliability: electrical stability | 5.2, 5.12 | Pass |
| 1) Response delays may not be a function of the input/output device, in which case no assessment is made as part of this standard | | |

The performance of the product identified above is in conformity with the performance and essential characteristics declared within this certificate. The declaration of performance is issued under the sole responsibility of Apollo Fire Detectors Limited.

Signed for and on behalf of Apollo Fire Detectors Limited by:



Mr. Karl Westhead
Technical Director

Place and Date of Issue: Havant – **01 November 2018**