



1 **EC-TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use**  
3 **in Potentially Explosive Atmospheres**  
4 **Directive 94/9/EC**

5 EC-Type Examination Certificate Number **RAS02ATEX1290**

6 Equipment or Protective System: **XP95 INTRINSICALLY SAFE MANUAL CALL POINT**

7 Manufacturer: **APOLLO FIRE DETECTORS LIMITED**

8 Address: **36 Brookside Road, Havant, Hampshire, PO9 1JH**

9 This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

10 The Electrical Equipment Certification Service, notified body number 600 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report N°

**02(C)0238 dated 25 September 2002**

11 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 50014: 1997 + Amds 1 & 2      EN 50020: 2002      EN 50284: 1999**

except in respect of those requirements listed at item 18 of the Schedule.

12 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

13 This EC-TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment or protective system.

14 The marking of the equipment or protective system shall include the following:-

**Ex II 1 G      EEx ia IIC T5 or EEx ia IIC T4 (-20°C < T<sub>a</sub> < 60°C)**

This certificate may only be reproduced in its entirety and without any change, schedule included.

File No: EECS 0073/02/020

This certificate is granted subject to the general conditions of the Electrical Equipment Certification Service. It does not necessarily indicate that the apparatus may be used in particular industries or circumstances.



Electrical Equipment Certification Service  
Health and Safety Executive  
Harpur Hill, Buxton, Derbyshire, SK17 9JN, United Kingdom  
Tel: +44(0)1298 28000 Fax: +44(0)1298 28244  
internet: www.bascefa.com e-mail: bascefa.info.eecs@hsl.gov.uk



**I M CLEARE**  
DIRECTOR  
25 September 2002



13 Schedule

14 EC-TYPE EXAMINATION CERTIFICATE N° BAS02ATEX1290

15 Description of Equipment or Protective System

The XP95 Intrinsically safe Manual Call Point is designed to initiate an alarm on a fire detector system.

The Manual Call Point comprises an electronics circuit mounted on a single printed circuit board, an LED and a switch located in a plastic enclosure. Connections to external circuits are made to terminal block TB1 located on the PCB via a cable entry gland.

Input Parameters at Terminal Block TB1

$U_i = 28V$                        $C_i = 0$   
 $I_i = 93.3 \text{ mA}$                  $L_i = 0$   
 $P_i = 0.67W$

16 Report No.

02(C)0238

17 Special Conditions For Safe Use

None.

18 Essential Health and Safety Requirements

None

19 DRAWINGS

Number	Sheet	Issue	Date	Description
55000-940CD	1	3	07/99	Circuit Diagram
43781-263	1	4	08/02	PCB Assembly
39855-957	1 & 2	4	01/00	PCB Machining & Artwork
55000-940 to 945	1	4	08/02	General Assembly
55000-960 to 967	1	3	08/02	General Assembly
55000-970 to 973	1	1	01/00	General Assembly
39117-516	1	2	08/02	Certification Label
39117-518	1	2	08/02	Certification Label

This certificate may only be reproduced in its entirety and without any change, schedule included.

BASEEFA List Keywords  
2FIREDET



1 **SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

- 3 Supplementary EC - Type Examination Certificate Number: **BAS02ATEX1290/1**
- 4 Equipment or Protective System: **XP95 INTRINSICALLY SAFE MANUAL CALL POINT**
- 5 Manufacturer: **APOLLO FIRE DETECTORS LIMITED**
- 6 Address: **36 Brookside Road, Havant, Hampshire, PO9 1JR**

- 7 This supplementary certificate extends EC – Type Examination Certificate No. BAS02ATEX1290 to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to

This supplementary certificate shall be held with the original certificate.

The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. Baseefa (2001) Ltd., Notified Body Number 1180, is responsible only for the additional work relating to this supplementary certificate and any other supplementary certificate it has issued.

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa (2001) Ltd. Customer Reference No. 0073

Project File No. 03/0693

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa (2001) Ltd.**  
Health and Safety Laboratory Site, Harpur Hill,  
Buxton, Derbyshire SK17 9JN  
Telephone +44 (0) 1298 28255 Fax +44 (0) 1298 28216  
e-mail [info@baseefa2001.biz](mailto:info@baseefa2001.biz) web site [www.baseefa2001.biz](http://www.baseefa2001.biz)  
Registered in England No. 4305578 at 13 Dovedale Crescent, Buxton,  
Derbyshire, SK17 9BJ

R S SINCLAIR  
DIRECTOR  
On behalf of  
Baseefa (2001) Ltd.



13

### Schedule

14

Certificate Number BAS02ATEX1290/1

15 Description of the variation to the Equipment or Protective System

#### Variation 1.1

To permit a minor variation to the identification label. Intrinsic Safety is not affected.

16 Report Number

None.

17 Special Conditions for Safe Use

None

18 Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 Drawings and Documents

Number	Sheets	Issue	Date	Description
55000-970-973 INCL	1	2	10/02	Push Button Waterproof Manual Call Point G.A



1 **SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres**  
*Directive 94/9/EC*

- 3 Supplementary EC - Type Examination Certificate Number: **BAS02ATEX1290/2**
- 4 Equipment or Protective System: **XP95 Intrinsically Safe Manual Call Point**
- 5 Manufacturer: **Apollo Fire Detectors Limited**
- 6 Address: **36 Brookside Road, Havant, Hampshire, PO9 1JR**
- 7 This supplementary certificate extends EC - Type Examination Certificate No. BAS02ATEX1290 to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. Baseefa (2001) Ltd., Notified Body Number 1180, is responsible only for the additional work relating to this supplementary certificate and any other supplementary certificate it has issued.


This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 0073

Project File No. 07/0394

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa**  
Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa (2001) Ltd  
Registered in England No. 4305578 at the above address

  
**R/S SINCLAIR**  
DIRECTOR  
On behalf of  
Baseefa (2001) Ltd.



13

### Schedule

14

Certificate Number BAS02ATEX1290X/2

15 **Description of the variation to the Equipment or Protective System**

#### Variation 2.1

To permit the use of a new plastic enclosure which does not affect the original assessment.  
A new single drawing replaces the older separate drawings.

16 **Report Number**

None.

17 **Special Conditions for Safe Use**

None additional to those listed previously

18 **Essential Health and Safety Requirements**

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 **Drawings and Documents**

Number	Sheet	Issue	Date	Description
55100-940CS	1 - 3	1	Jan 08	XP95 Intrinsically Safe Manual Call Point



1 **SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

- 3 Supplementary EC - Type Examination Certificate Number: **BAS02ATEX1290/3**
- 4 Equipment or Protective System: **XP95 Intrinsically Safe Manual Call Point**
- 5 Manufacturer: **Apollo Fire Detectors Limited**
- 6 Address: **36 Brookside Road, Havant, Hampshire, PO9 1JR**
- 7 This supplementary certificate extends EC – Type Examination Certificate No. BAS02ATEX1290 to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.


The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. Baseefa, Notified Body Number 1180, is responsible only for the additional work relating to this supplementary certificate and any other supplementary certificate it has issued.

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 0073

Project File No. 09/0143

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

  
PP D BREARLEY

**Baseefa**  
Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa Ltd  
Registered in England No. 4305578. Registered address as above.

R S SINCLAIR  
DIRECTOR  
On behalf of  
Baseefa



13

**Schedule**

14

**Certificate Number BAS02ATEX1290/3**

15 **Description of the variation to the Equipment or Protective System**

**Variation 3.1**

To permit minor drawing changes that do not affect the original assessment.

16 **Report Number**

None.

17 **Special Conditions for Safe Use**

None.

18 **Essential Health and Safety Requirements**

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 **Drawings and Documents**

<b>Number</b>	<b>Sheet</b>	<b>Issue</b>	<b>Date</b>	<b>Description</b>
55100-940CS	1 – 3	2	Jan 09	XP95 Intrinsically Safe Manual Call Point





**1 SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

**2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

**3 Supplementary EC - Type Examination Certificate Number: BAS02ATEX1290/4**

**4 Equipment or Protective System: XP95 Intrinsically Safe Manual Call Point**

**5 Manufacturer: Apollo Fire Detectors Limited**

**6 Address: 36 Brookside Road, Havant, Hampshire, PO9 1JR**

**7 This supplementary certificate extends EC - Type Examination Certificate No. BAS02ATEX1290 to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.**

This supplementary certificate shall be held with the original certificate.

The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. Baseefa, Notified Body Number 1180, is responsible only for the additional work relating to this supplementary certificate and any other supplementary certificate it has issued.

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 0073

Project File No. 09/0926

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

A handwritten signature in blue ink, appearing to read "R S Sinclair".

**Baseefa**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa Ltd  
Registered in England No. 4305578. Registered address as above.

**R S SINCLAIR**  
DIRECTOR  
On behalf of  
Baseefa



13

### Schedule

14

Certificate Number BAS02ATEX1290/4

15

Description of the variation to the Equipment or Protective System

#### Variation 4.1

To permit minor drawing changes which do not affect the original assessment.

16

Report Number

None.

17

Special Conditions for Safe Use

None.

18

Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19

Drawings and Documents

Number	Sheet	Issue	Date	Description
55000-940CD	1 of 1	3A	Nov 09	XP95 Int. Safe Manual Call Point Schematic Diagram

Certificate Number  
**BAS02ATEX1290**  
Issue 5



Issued 11 July 2011  
Page 1 of 3

**1 EC - TYPE EXAMINATION CERTIFICATE**

**2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

**3 EC - Type Examination Certificate Number: BAS02ATEX1290 – Issue 5**

**4 Equipment or Protective System: XP95 Intrinsically Safe Manual Call Point**

**5 Manufacturer: Apollo Fire Detectors Limited**

**6 Address: 36 Brookside Road, Havant, Hampshire, PO9 1JR**

**7 This re-issued certificate extends EC – Type Examination Certificate No. BAS02ATEX1290 to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to**

**8 The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. Baseefa, Notified Body Number 1180, is responsible only for the additional work relating to this re-issued certificate and any other supplementary certificate it has issued.**

The examination and test results are recorded in confidential Report No. None

**9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:**

**EN60079-0:2009 EN60079-11:2007**

except in respect of those requirements listed at item 18 of the Schedule.

**10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.**

**11 This EC – TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.**

**12 The marking of the equipment or protective system shall include the following :**

**⊕ II 1G Ex ia IIC T5 Ga (-20°C ≤ Ta ≤ +45°C) or Ex ia IIC T4 Ga (-20°C < Ta ≤ 60°C)**

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 0073

Project File No. 11/0518

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**R S SINCLAIR**  
**DIRECTOR**  
On behalf of  
Baseefa

**Baseefa**  
Rockhead Business Park, Staddon Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa Ltd  
Registered in England No. 4305578. Registered address as above.



13

### Schedule

14

Certificate Number BAS02ATEX1290 – Issue 5

15 **Description of Equipment or Protective System**

The XP95 Intrinsically Safe Manual Call Point is designed to initiate an alarm on a fire detector system.

The Manual Call Point comprises an electronics circuit mounted on a single printed circuit board, an LED and a switch located in a plastic enclosure. Connections to external circuits are made to terminal block TB1 located on the PCB via a cable entry gland.

**Input Parameters at Terminal Block TB1:**

$$U_o = 28V \quad C_i = 0$$

$$I_o = 93.3mA \quad L_i = 0$$

$$P_o = 0.67W$$

16 **Report Number**

None

17 **Special Conditions for Safe Use**

The enclosure and junction box or connector body may be plastic, do not clean with solvents or charge by rubbing.

18 **Essential Health and Safety Requirements**

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

19 **Drawings and Documents**

Number	Sheet	Issue	Date	Description
39117-518	1 of 1	4	Jul 11	XP95 I.S. Manual Call Point Certification Plate Label
39117-713	1 of 1	2	Jul 11	XP95 I.S. Manual Call Point Certification Label
43781-263	1 of 1	5	Jul 11	XP95 Intrinsically Safe Manual Call Point PCB Assembly
55100-940CS	1 – 3	3	Jul 11	XP95 Intrinsically Safe Manual Call Point
55000-960-967INCL	1 of 1	4	Jul 11	XP95 Intrinsically Safe Waterproof Manual Call Point General Assembly
55000-970-973INCL	1 of 1	3	Jul 11	Push Button Waterproof Manual Call Point General Assembly



20 Certificate History

Certificate No.	Date	Comments
BAS02ATEX1290	25 September 2002	The release of the prime certificate. The associated test and assessment against the requirements of EN50014:1997 + Amds 1 & 2, EN50020:2002 and EN50284:1999 is documented in Test Report No. 02(C)0238.
BAS02ATEX1290/1	6 August 2003	To permit a minor variation to the identification label. Intrinsic Safety is not affected.
BAS02ATEX1290/2	18 January 2008	To permit the use of a new plastic enclosure which does not affect the original assessment. A new single drawing replaces the older separate drawings.
BAS02ATEX1290/3	11 February 2009	To permit minor drawing changes that do not affect the original assessment
BAS02ATEX1290/4	12 January 2010	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290 Issue 5	11 July 2011	To permit minor drawing changes that do not affect the original assessment and a change to the T5 ambient temperature range. The range is now $-20^{\circ}\text{C} < T_a \leq +45^{\circ}\text{C}$ .  This issue of the certificate also incorporates previously issued primary & supplementary certificates into one certificate and, following minor changes to the PCBs, confirms the current design meets the requirements of EN60079-0:2009 and EN60079-11:2007.

For drawings applicable to each issue, see original of that issue.

3089.02

Certificate Number  
**BAS02ATEX1290**  
Issue 6



Issued 30 August 2012  
Page 1 of 3

1 **EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres**  
**Directive 94/9/EC**

- 3 EC - Type Examination Certificate Number: **BAS02ATEX1290 – Issue 6**
- 4 Equipment or Protective System: **XP95 Intrinsically Safe Manual Call Point**
- 5 Manufacturer: **Apollo Fire Detectors Limited**
- 6 Address: **36 Brookside Road, Havant, Hampshire, PO9 1JR**

7 This re-issued certificate extends EC – Type Examination Certificate No. BAS02ATEX1290 to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to

8 The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. Baseefa, Notified Body Number 1180, is responsible only for the additional work relating to this re-issued certificate and any other supplementary certificate it has issued.

The examination and test results are recorded in confidential Report No's. None

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:  
**EN60079-0:2009 EN60079-11:2007**

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

12 The marking of the equipment or protective system shall include the following :

II IG Ex ia IIC T5 Ga (-20°C ≤ Ta ≤ +45°C) or Ex ia IIC T4 Ga (-20°C ≤ Ta ≤ 60°C)

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 0073

Project File No. 12/0446

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa**  
Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa Ltd  
Registered in England No. 4305578. Registered address as above.

**R S SINCLAIR**  
DIRECTOR  
On behalf of  
Dasccfa



13

### Schedule

14

Certificate Number BAS02ATEX1290 – Issue 6

#### 15 Description of Equipment or Protective System

The XP95 Intrinsically Safe Manual Call Point is designed to initiate an alarm on a fire detector system.

The Manual Call Point comprises an electronics circuit mounted on a single printed circuit board, an LED and a switch located in a plastic enclosure. Connections to external circuits are made to terminal block TB1 located on the PCB via a cable entry gland.

#### Input Parameters at Terminal Block TB1:

$U_i = 28V$        $C_i = 0$

$I_i = 93.3mA$      $L_i = 0$

$P_i = 0.67W$

#### 16 Report Number

None

#### 17 Specific Conditions of Use

None

#### 18 Essential Health and Safety Requirements

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

#### 19 Drawings and Documents

New drawings submitted for this issue of certificate.

Number	Sheet	Issue	Date	Description
55100-940CS	1 – 3	4	Mar 12	XP95 Intrinsically Safe Manual Call Point

Current drawings also associated with this certificate.

Number	Sheet	Issue	Date	Description
39117-518	1 of 1	4	Jul 11	XP95 I.S. Manual Call Point Certification Plate Label
39117-713	1 of 1	2	Jul 11	XP95 I.S. Manual Call Point Certification Label
43781-263	1 of 1	5	Jul 11	XP95 Intrinsically Safe Manual Call Point PCB Assembly
55000-960-967INCL	1 of 1	4	Jul 11	XP95 Intrinsically Safe Waterproof Manual Call Point General Assembly
55000-970-973INCL	1 of 1	3	Jul 11	Push Button Waterproof Manual Call Point General Assembly



20 Certificate History

Certificate No.	Date	Comments
BAS02ATEX1290	25 September 2002	The release of the prime certificate. The associated test and assessment against the requirements of EN50014:1997 + Amds 1 & 2, EN50020:2002 and EN50284:1999 is documented in Test Report No. 02(C)0238.
BAS02ATEX1290/1	6 August 2003	To permit a minor variation to the identification label. Intrinsic Safety is not affected.
BAS02ATEX1290/2	18 January 2008	To permit the use of a new plastic enclosure which does not affect the original assessment. A new single drawing replaces the older separate drawings.
BAS02ATEX1290/3	11 February 2009	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290/4	12 January 2010	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290 Issue 5	11 July 2011	To permit minor drawing changes that do not affect the original assessment and a change to the T5 ambient temperature range. The range is now $-20^{\circ}\text{C} \leq T_a \leq +45^{\circ}\text{C}$ .  This issue of the certificate also incorporates previously issued primary & supplementary certificates into one certificate and, following minor changes to the PCBs, confirms the current design meets the requirements of EN60079-0:2009 and EN60079-11:2007.
BAS02ATEX1290 Issue 6	30 August 2012	To permit minor drawing changes that do not affect the original assessment and to correct the input parameters.

For drawings applicable to each issue, see original of that issue.



Certificate Number  
**BAS02ATEX1290**  
 Issue 7



Issued 16 November 2012  
 Page 1 of 3

- 1 EC - TYPE EXAMINATION CERTIFICATE**
- 2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
 Directive 94/9/EC**
- 3 EC - Type Examination Certificate Number: BAS02ATEX1290 – Issue 7**
- 4 Equipment or Protective System: XP95 Intrinsically Safe Manual Call Point**
- 5 Manufacturer: Apollo Fire Detectors Limited**
- 6 Address: 36 Brookside Road, Havant, Hampshire, PO9 1JR**
- 7** This re-issued certificate extends EC Type Examination Certificate No. BAS02ATEX1290 to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to
- 8** The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. Baseefa, Notified Body Number 1180, is responsible only for the additional work relating to this re-issued certificate and any other supplementary certificate it has issued.
- The examination and test results are recorded in confidential Report No's. GB/BAS/ExTR12.0292/00
- 9** Compliance with the Essential Health and Safety Requirements has been assured by compliance with:  
**EN60079-0:2012 EN60079-11:2012**  
 except in respect of those requirements listed at item 18 of the Schedule.
- 10** If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- 11** This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- 12** The marking of the equipment or protective system shall include the following :
- (Ex) II 1G Ex ia IIC T5 Ga (-20°C ≤Ta ≤+45°C) or Ex ia IIC T4 Ga (-20°C ≤Ta ≤60°C)**
- This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 0073

Project File No. 12/0554

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa**  
 Rockhead Business Park, Staden Lane,  
 Buxton, Derbyshire SK17 9RZ  
 Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
 e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
 Baseefa is a trading name of Baseefa Ltd  
 Registered in England No. 4305578. Registered address as above.

  
**R S SINCLAIR**  
 DIRECTOR  
 On behalf of  
 Baseefa



13

## Schedule

14

Certificate Number BAS02ATEX1290 – Issue 7

15

### Description of Equipment or Protective System

The XP95 Intrinsically Safe Manual Call Point is designed to initiate an alarm on a fire detector system.

The Manual Call Point comprises an electronics circuit mounted on a single printed circuit board, an LED and a switch located in a plastic enclosure. Connections to external circuits are made to terminal block TB1 located on the PCB via a cable entry gland.

#### Input Parameters at Terminal Block TB1:

$$U_i = 28V \quad C_i = 0$$

$$I_i = 93.3mA \quad L_i = 0$$

$$P_i = 0.67W$$

16

### Report Number

None

17

### Specific Conditions of Use

None

18

### Essential Health and Safety Requirements

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

19

### Drawings and Documents

New drawings submitted for this issue of certificate.

Number	Sheet	Issue	Date	Description
55100-940CS	1 – 3	5	Sep 12	XP95 Intrinsically Safe Manual Call Point



Current drawings also associated with this certificate.

Number	Sheet	Issue	Date	Description
39117-518	1 of 1	4	Jul 11	XP95 I.S. Manual Call Point Certification Plate Label
39117-713	1 of 1	2	Jul 11	XP95 I.S. Manual Call Point Certification Label
43781-263	1 of 1	5	Jul 11	XP95 Intrinsically Safe Manual Call Point PCB Assembly
55000-960-967INCL	1 of 1	4	Jul 11	XP95 Intrinsically Safe Waterproof Manual Call Point General Assembly
55000-970-973INCL	1 of 1	3	Jul 11	Push Button Waterproof Manual Call Point General Assembly



20 Certificate History

Certificate No.	Date	Comments
BAS02ATEX1290	25 September 2002	The release of the prime certificate. The associated test and assessment against the requirements of EN50014:1997 + Amds 1 & 2, EN50020:2002 and EN50284:1999 is documented in Test Report No. 02(C)0238.
BAS02ATEX1290/1	6 August 2003	To permit a minor variation to the identification label. Intrinsic Safety is not affected.
BAS02ATEX1290/2	18 January 2008	To permit the use of a new plastic enclosure which does not affect the original assessment. A new single drawing replaces the older separate drawings.
BAS02ATEX1290/3	11 February 2009	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290/4	12 January 2010	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290 Issue 5	11 July 2011	To permit minor drawing changes that do not affect the original assessment and a change to the T5 ambient temperature range. The range is now $-20^{\circ}\text{C} \leq T_a \leq +45^{\circ}\text{C}$ .  This issue of the certificate also incorporates previously issued primary & supplementary certificates into one certificate and, following minor changes to the PCBs, confirms the current design meets the requirements of EN60079-0:2009 and EN60079-11:2007.
BAS02ATEX1290 Issue 6	30 August 2012	To permit minor drawing changes that do not affect the original assessment and to correct the input parameters.
BAS02ATEX1290 Issue 7	16 November 2012	To permit minor drawing changes that do not affect the original assessment and to confirm that the current design meets the requirements of EN60079-0:2012 and EN60079-11:2012.
For drawings applicable to each issue, see original of that issue.		

- 1 EC - TYPE EXAMINATION CERTIFICATE**
- 2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**
- 3 EC - Type Examination Certificate Number: BAS02ATEX1290X – Issue 8**
- 4 Equipment or Protective System: XP95 Intrinsically Safe Manual Call Point**
- 5 Manufacturer: Apollo Fire Detectors Limited**
- 6 Address: 36 Brookside Road, Havant, Hampshire, PO9 1JR**
- 7** This re-issued certificate extends EC – Type Examination Certificate No. BAS02ATEX1290X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to
- 8** The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. Baseefa, Notified Body Number 1180, is responsible only for the additional work relating to this re-issued certificate and any other supplementary certificate it has issued.
- The examination and test results are recorded in confidential Report No's. Certificate History
- 9** Compliance with the Essential Health and Safety Requirements has been assured by compliance with:  
**EN 60079-0:2012 EN 60079-11:2012**  
except in respect of those requirements listed at item 18 of the Schedule.
- 10** If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- 11** This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- 12** The marking of the equipment or protective system shall include the following :
-  **Ex ia IIC T5 Ga (-20°C ≤Ta ≤+45°C) or Ex ia IIC T4 Ga (-20°C ≤Ta ≤60°C) or**  
 **Ex ia IIC T135°C Da (-20°C ≤Ta ≤+60°C)**

Baseefa Customer Reference No. **0073**

Project File No. **12/1015**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGS Baseefa Limited**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN

  
R S SINCLAIR  
GENERAL MANAGER  
On behalf of SGS Baseefa Limited

13

## Schedule

14

Certificate Number BAS02ATEX1290X – Issue 8

### 15 Description of Equipment or Protective System

The XP95 Intrinsically Safe Manual Call Point is designed to initiate an alarm on a fire detector system.

The Manual Call Point comprises an electronics circuit mounted on a single printed circuit board, an LED and a switch located in a plastic enclosure. Connections to external circuits are made to terminal block TB1 located on the PCB via a cable entry gland.

#### Input Parameters (all versions)

##### Terminal Block TB1:

$$U_i = 28V \quad C_i = 0$$

$$I_i = 93.3mA \quad L_i = 0$$

$$P_i = 0.67W$$

### 16 Report Number

GB/BAS/ExTR13.0090/00

### 17 Specific Conditions of Use

1. The enclosure may constitute a potential electrostatic ignition hazard and must not be rubbed or cleaned with a dry cloth or mounted in dust laden airflow.

### 18 Essential Health and Safety Requirements

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

### 19 Drawings and Documents

New drawings submitted for this issue of certificate.

Number	Sheet	Issue	Date	Description
55100-940CS	1 – 3	6	Apr 13	XP95 Intrinsically Safe Manual Call Point
55200-940CS	1 – 3	B	Apr 13	XP95 Intrinsically Safe Manual Call Point

Current drawings also associated with this certificate.

Number	Sheet	Issue	Date	Description
39117-518	1 of 1	4	Jul 11	XP95 I.S. Manual Call Point Certification Plate Label
39117-713	1 of 1	2	Jul 11	XP95 I.S. Manual Call Point Certification Label
43781-263	1 of 1	5	Jun 11	XP95 Intrinsically Safe Manual Call Point PCB Assembly
55000-960-967INCL	1 of 1	4	Jun 11	XP95 Intrinsically Safe Waterproof Manual Call Point General Assembly
55000-970-973INCL	1 of 1	3	Jul 11	Push Button Waterproof Manual Call Point General Assembly

20 Certificate History

Certificate No.	Date	Comments
BAS02ATEX1290	25 September 2002	The release of the prime certificate. The associated test and assessment against the requirements of EN50014:1997 + Amds 1 & 2, EN50020:2002 and EN50284:1999 is documented in Test Report No. 02(C)0238.
BAS02ATEX1290/1	6 August 2003	To permit a minor variation to the identification label. Intrinsic Safety is not affected.
BAS02ATEX1290/2	18 January 2008	To permit the use of a new plastic enclosure which does not affect the original assessment. A new single drawing replaces the older separate drawings.
BAS02ATEX1290/3	11 February 2009	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290/4	12 January 2010	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290 Issue 5	11 July 2011	To permit minor drawing changes that do not affect the original assessment and a change to the T5 ambient temperature range. The range is now $-20^{\circ}\text{C} \leq T_a \leq +45^{\circ}\text{C}$ .  This issue of the certificate also incorporates previously issued primary & supplementary certificates into one certificate and, following minor changes to the PCBs, confirms the current design meets the requirements of EN60079-0:2009 and EN60079-11:2007.
BAS02ATEX1290 Issue 6	30 August 2012	To permit minor drawing changes that do not affect the original assessment and to correct the input parameters.
BAS02ATEX1290 Issue 7	16 November 2012	To permit minor drawing changes that do not affect the original assessment and to confirm that the current design meets the requirements of EN60079-0:2012 and EN60079-11:2012.
BAS02ATEX1290X Issue 8	17 April 2013	To permit the introduction of an alternative XP95 Manual Call Point, defined by drawing 55200-940CS, which additionally carries the following marking:  <b>⊕ II 1D Ex ia IIC T135°C Da (-20°C ≤ T<sub>a</sub> ≤ +60°C)</b>  The input parameters for all variants are identical to the original parameters and are as stated above.  To confirm that a special condition of safe use applies to both designs of Manual Call Points; this states that the enclosure may constitute a potential electrostatic ignition hazard and must not be rubbed or cleaned with a dry cloth or mounted in dust laden airflow.  This issue is supported by test report GB/BAS/ExTR13.0090/00.

For drawings applicable to each issue, see original of that issue.

1 **EC - TYPE EXAMINATION CERTIFICATE**  
 2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres**  
 Directive 94/9/EC

- 3 EC - Type Examination Certificate Number: **BAS02ATEX1290X – Issue 9**
- 4 Equipment or Protective System: **XP95 Intrinsically Safe Manual Call Point**
- 5 Manufacturer: **Apollo Fire Detectors Limited**
- 6 Address: **36 Brookside Road, Havant, Hampshire, PO9 1JR**
- 7 This re-issued certificate extends EC – Type Examination Certificate No. BAS02ATEX1290X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to
- 8 The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. Baseefa, Notified Body Number 1180, is responsible only for the additional work relating to this re-issued certificate and any other supplementary certificate it has issued.
- The examination and test results are recorded in confidential Report No's. See Certificate History
- 9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:  
**EN 60079-0:2012 EN 60079-11:2012**  
 except in respect of those requirements listed at item 18 of the Schedule.
- 10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- 11 This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- 12 The marking of the equipment or protective system shall include the following :
- (Ex) II 1G Ex ia IIC T5 Ga (-20°C ≤Ta ≤+45°C) or Ex ia IIC T4 Ga (-20°C ≤Ta ≤60°C) or  
 (Ex) II 1D Ex ia IIC T135°C Da (-20°C ≤Ta ≤+60°C)

Baseefa Customer Reference No. **0073**

Project File No. **13/0986**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGS Baseefa Limited**

Rockhead Business Park, Staden Lane,  
 Buxton, Derbyshire SK17 9RZ  
 Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
 e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
 Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN



**R S SINCLAIR**  
 GENERAL MANAGER

On behalf of SGS Baseefa Limited

13 **Schedule**

14 **Certificate Number BAS02ATEX1290X – Issue 9**

15 **Description of Equipment or Protective System**

The XP95 Intrinsically Safe Manual Call Point is designed to initiate an alarm on a fire detector system.

The Manual Call Point comprises an electronics circuit mounted on a single printed circuit board, an LED and a switch located in a plastic enclosure. Connections to external circuits are made to terminal block TB1 located on the PCB via a cable entry gland.

**Input Parameters (all versions)**

**Terminal Block TB1:**

$$U_i = 28V \quad C_i = 0$$

$$I_i = 93.3mA \quad L_i = 0$$

$$P_i = 0.67W$$

16 **Report Number**

GB/BAS/ExTR13.0293/00

17 **Specific Conditions of Use**

1. The enclosure may constitute a potential electrostatic ignition hazard and must not be rubbed or cleaned with a dry cloth or mounted in dust laden airflow.

18 **Essential Health and Safety Requirements**

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

19 **Drawings and Documents**

New drawings submitted for this issue of certificate.

Number	Sheet	Issue	Date	Description
55200-940CS	1 – 3	1	Nov 13	XP95 Intrinsically Safe Manual Call Point

Current drawings also associated with this certificate.

Number	Sheet	Issue	Date	Description
39117-518	1 of 1	4	Jul 11	XP95 I.S. Manual Call Point Certification Plate Label
39117-713	1 of 1	2	Jul 11	XP95 I.S. Manual Call Point Certification Label
43781-263	1 of 1	5	Jul 11	XP95 Intrinsically Safe Manual Call Point PCB Assembly
55000-960-967INCL	1 of 1	4	Jul 11	XP95 Intrinsically Safe Waterproof Manual Call Point General Assembly
55000-970-973INCL	1 of 1	3	Jul 11	Push Button Waterproof Manual Call Point General Assembly
55100-940CS	1 – 3	6	Apr 13	XP95 Intrinsically Safe Manual Call Point



20 Certificate History

Certificate No.	Date	Comments
BAS02ATEX1290	25 September 2002	The release of the prime certificate. The associated test and assessment against the requirements of EN50014:1997 – Amendments 1 & 2, EN50020:2002 and EN50284:1999 is documented in Test Report No. 02(C)0238.
BAS02ATEX1290/1	6 August 2003	To permit a minor variation to the identification label. Intrinsic Safety is not affected.
BAS02ATEX1290/2	18 January 2008	To permit the use of a new plastic enclosure which does not affect the original assessment. A new single drawing replaces the older separate drawings.
BAS02ATEX1290/3	11 February 2009	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290/4	12 January 2010	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290 Issue 5	11 July 2011	To permit minor drawing changes that do not affect the original assessment and a change to the T5 ambient temperature range. The range is now $-20^{\circ}\text{C} \leq T_a \leq -45^{\circ}\text{C}$ .  This issue of the certificate also incorporates previously issued primary & supplementary certificates into one certificate and, following minor changes to the PCBs, confirms the current design meets the requirements of EN60079-0:2009 and EN60079-11:2007.
BAS02ATEX1290 Issue 6	30 August 2012	To permit minor drawing changes that do not affect the original assessment and to correct the input parameters.
BAS02ATEX1290 Issue 7	16 November 2012	To permit minor drawing changes that do not affect the original assessment and to confirm that the current design meets the requirements of EN60079-0:2012 and EN60079-11:2012.
BAS02ATEX1290X Issue 8	17 April 2013	To permit the introduction of an alternative XP95 Manual Call Point, defined by drawing 55200-940CS, which additionally carries the following marking:  <b>Ⓔ II 1D Ex ia IIC T135°C Da (-20°C ≤ T<sub>a</sub> ≤ +60°C)</b>  The input parameters for all variants are identical to the original parameters and are as stated above.  To confirm that a special condition of safe use applies to both designs of Manual Call Points; this states that the enclosure may constitute a potential electrostatic ignition hazard and must not be rubbed or cleaned with a dry cloth or mounted in dust laden airflow.  This issue is supported by test report GB/BAS/ExTR13.0090/00. Project File No. 12/1015.
BAS02ATEX1290X Issue 9	3 December 2013	To permit minor drawing changes that do not affect the original assessment.  This issue is supported by test report GB/BAS/ExTR13.0293/00. Project File No. 13/0986.

For drawings applicable to each issue, see original of that issue.

1 **EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres**  
**Directive 94/9/EC**

3 EC - Type Examination Certificate Number: **BAS02ATEX1290X – Issue 10**

4 Equipment or Protective System: **XP95 Intrinsically Safe Manual Call Point**

5 Manufacturer: **Apollo Fire Detectors Limited**

6 Address: **36 Brookside Road, Havant, Hampshire, PO9 1JR**

7 This re-issued certificate extends EC – Type Examination Certificate No. BAS02ATEX1290X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to

8 The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. Baseefa, Notified Body Number 1180, is responsible only for the additional work relating to this re-issued certificate and any other supplementary certificate it has issued.

The examination and test results are recorded in confidential Report No's. See Certificate History

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:



**EN 60079-0:2012 EN 60079-11:2012**

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

12 The marking of the equipment or protective system shall include the following :

 II 1G Ex ia IIC T5 Ga (-20°C ≤Ta ≤+45°C) or Ex ia IIC T4 Ga (-20°C ≤Ta ≤60°C) or  
 II 1D Ex ia IIIC T135°C Da (-20°C ≤Ta ≤+60°C)

Baseefa Customer Reference No. 0073

Project File No. 14/0988

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGS Baseefa Limited**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN

  
R S SINCLAIR

GENERAL MANAGER

On behalf of SGS Baseefa Limited

13

## Schedule

14

Certificate Number BAS02ATEX1290X – Issue 10

### 15 Description of Equipment or Protective System

The XP95 Intrinsically Safe Manual Call Point is designed to initiate an alarm on a fire detector system.

The Manual Call Point comprises an electronics circuit mounted on a single printed circuit board, an LED and a switch located in a plastic enclosure. Connections to external circuits are made to terminal block TB1 located on the PCB via a cable entry gland.

#### Input Parameters (all versions)

##### Terminal Block TB1:

$$U_i = 28V \quad C_i = 0$$

$$I_i = 93.3mA \quad L_i = 0$$

$$P_i = 0.67W$$

### 16 Report Number

GB/BAS/ExTR15.0059/00

### 17 Specific Conditions of Use

1. The enclosure may constitute a potential electrostatic ignition hazard and must not be rubbed or cleaned with a dry cloth or mounted in dust laden airflow.

### 18 Essential Health and Safety Requirements

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

### 19 Drawings and Documents

New drawings submitted for this issue of certificate.

Number	Sheet	Issue	Date	Description
55100-940CS	1 – 3	7	Nov 14	XP95 Intrinsically Safe Manual Call Point
55200-940CS	1 – 3	2	Nov 14	XP95 Intrinsically Safe Manual Call Point
39117-518	1 of 1	5	Nov 14	XP95 I.S. Manual Call Point Certification Plate Label

Current drawings also associated with this certificate.

Number	Sheet	Issue	Date	Description
39117-713	1 of 1	2	Jul 11	XP95 I.S. Manual Call Point Certification Label
43781-263	1 of 1	5	Jul 11	XP95 Intrinsically Safe Manual Call Point PCB Assembly
55000-960-967INCL	1 of 1	4	Jul 11	XP95 Intrinsically Safe Waterproof Manual Call Point General Assembly
55000-970-973INCL	1 of 1	3	Jul 11	Push Button Waterproof Manual Call Point General Assembly

All drawings are common to, and held with, IECEx BAS 12.0091X Issue 3.

20 Certificate History

Certificate No.	Date	Comments
BAS02ATEX1290	25 September 2002	The release of the prime certificate. The associated test and assessment against the requirements of EN50014:1997 + Amds 1 & 2, EN50020:2002 and EN50284:1999 is documented in Test Report No. 02(C)0238.
BAS02ATEX1290/1	6 August 2003	To permit a minor variation to the identification label. Intrinsic Safety is not affected.
BAS02ATEX1290/2	18 January 2008	To permit the use of a new plastic enclosure which does not affect the original assessment. A new single drawing replaces the older separate drawings.
BAS02ATEX1290/3	11 February 2009	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290/4	12 January 2010	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290 Issue 5	11 July 2011	To permit minor drawing changes that do not affect the original assessment and a change to the T5 ambient temperature range. The range is now $-20^{\circ}\text{C} \leq T_a \leq +45^{\circ}\text{C}$ . This issue of the certificate also incorporates previously issued primary & supplementary certificates into one certificate and, following minor changes to the PCBs, confirms the current design meets the requirements of EN60079-0:2009 and EN60079-11:2007.
BAS02ATEX1290 Issue 6	30 August 2012	To permit minor drawing changes that do not affect the original assessment and to correct the input parameters.
BAS02ATEX1290 Issue 7	16 November 2012	To permit minor drawing changes that do not affect the original assessment and to confirm that the current design meets the requirements of EN60079-0:2012 and EN60079-11:2012.
BAS02ATEX1290X Issue 8	17 April 2013	To permit the introduction of an alternative XP95 Manual Call Point, defined by drawing 55200-940CS, which additionally carries the following marking: <b>⊕ II 1D Ex ia III C T135°C Da (-20°C ≤ T<sub>a</sub> ≤ +60°C)</b> The input parameters for all variants are identical to the original parameters and are as stated above. To confirm that a special condition of safe use applies to both designs of Manual Call Points; this states that the enclosure may constitute a potential electrostatic ignition hazard and must not be rubbed or cleaned with a dry cloth or mounted in dust laden airflow. This issue is supported by test report GB/BAS/ExTR13.0090/00. Project File No. 12/1015.
BAS02ATEX1290X Issue 9	3 December 2013	To permit minor drawing changes that do not affect the original assessment. This issue is supported by test report GB/BAS/ExTR13.0293/00. Project File No. 13/0986.
BAS02ATEX1290X Issue 10	23 February 2015	To permit minor label changes. Test Report GB/BAS/ExTR15.0059/00. Project File No. 14/0988.
For drawings applicable to each issue, see original of that issue.		

1 **EU - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 2014/34/EU**

3 EU - Type Examination Certificate **BAS02ATEX1290X – Issue 11**  
Number:

3.1 In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

4 Product: **XP95 Intrinsically Safe Manual Call Point**

5 Manufacturer: **Apollo Fire Detectors Limited**

6 Address: **36 Brookside Road, Havant, Hampshire, PO9 1JR**

7 This re-issued certificate extends EC - Type Examination Certificate No. BAS02ATEX1290X to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to

8 The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. SGS Baseefa, Notified Body Number 1180, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, is responsible only for the additional work relating to this re-issued certificate and any other supplementary certificate it has issued.

The examination and test results are recorded in confidential Report No. **See Certificate History**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 60079-0:2012+A11:2013 EN 60079-11:2012**

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign “X” is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following :

⊕ II 1G Ex ia IIC T5 Ga (-20°C ≤ Ta ≤ +45°C) or Ex ia IIC T4 Ga (-20°C ≤ Ta ≤ 60°C) or  
⊕ II 1D Ex ia IIIC T135°C Da (-20°C ≤ Ta ≤ +60°C)

SGS Baseefa Customer Reference No. **0073**

Project File No. **17/0348**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGS Baseefa Limited**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [baseefa@sgs.com](mailto:baseefa@sgs.com) web site [www.sgs.co.uk/baseefa](http://www.sgs.co.uk/baseefa)

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN

*PP McFarney*  
*McFarney*

R S SINCLAIR

TECHNICAL MANAGER

On behalf of SGS Baseefa Limited

13 **Schedule**

14 **Certificate Number BAS02ATEX1290X – Issue 11**

15 **Description of Product**

The XP95 Intrinsically Safe Manual Call Point is designed to initiate an alarm on a fire detector system.

The Manual Call Point comprises an electronics circuit mounted on a single printed circuit board, an LED and a switch located in a plastic enclosure. Connections to external circuits are made to terminal block TB1 located on the PCB via a cable entry gland.

**Input Parameters (all versions)**

**Terminal Block TB1:**

$$U_i = 28V \quad C_i = 0$$

$$I_i = 93.3mA \quad L_i = 0$$

$$P_i = 0.67W$$

16 **Report Number**

See Certificate History.

17 **Specific Conditions of Use**

1. The enclosure may constitute a potential electrostatic ignition hazard and must not be rubbed or cleaned with a dry cloth or mounted in dust laden airflow.

18 **Essential Health and Safety Requirements**

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product:

Clause	Subject	Compliance
1.2.7	LVD type requirements	Manufacturer responsibility
1.2.8	Overloading of equipment (protection relays, etc.)	User/Installer responsibility
1.4.1	External effects	User/Installer responsibility
1.4.2	Aggressive substances, etc.	User/Installer responsibility

19 **Drawings and Documents**

New drawings submitted for this issue of certificate.

Number	Sheet	Issue	Date	Description
39117-518	1 of 1	5	Nov 14	XP95 I.S. Manual Call Point Certification Plate Label
55100-940CS	1 – 3	8	Sep 15	XP95 Intrinsically Safe Manual Call Point
55200-940CS	1 – 3	2	Nov 14	XP95 Intrinsically Safe Manual Call Point

Current drawings also associated with this certificate.

Number	Sheet	Issue	Date	Description
55000-960-967INCL	1 of 1	4	Jul 11	XP95 Intrinsically Safe Waterproof Manual Call Point General Assembly
55000-970-973INCL	1 of 1	3	Jul 11	Push Button Waterproof Manual Call Point General Assembly

All drawings are common to, and held with, IECEx BAS 12.0091X.

20 Certificate History

Certificate No.	Date	Comments
BAS02ATEX1290	25 September 2002	The release of the prime certificate. The associated test and assessment against the requirements of EN50014:1997 + Amds 1 & 2, EN50020:2002 and EN50284:1999 is documented in Test Report No. 02(C)0238.
BAS02ATEX1290/1	6 August 2003	To permit a minor variation to the identification label. Intrinsic Safety is not affected.
BAS02ATEX1290/2	18 January 2008	To permit the use of a new plastic enclosure which does not affect the original assessment. A new single drawing replaces the older separate drawings.
BAS02ATEX1290/3	11 February 2009	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290/4	12 January 2010	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290 Issue 5	11 July 2011	To permit minor drawing changes that do not affect the original assessment and a change to the T5 ambient temperature range. The range is now $-20^{\circ}\text{C} \leq \text{Ta} \leq +45^{\circ}\text{C}$ .  This issue of the certificate also incorporates previously issued primary & supplementary certificates into one certificate and, following minor changes to the PCBs, confirms the current design meets the requirements of EN60079-0:2009 and EN60079-11:2007.
BAS02ATEX1290 Issue 6	30 August 2012	To permit minor drawing changes that do not affect the original assessment and to correct the input parameters.
BAS02ATEX1290 Issue 7	16 November 2012	To permit minor drawing changes that do not affect the original assessment and to confirm that the current design meets the requirements of EN60079-0:2012 and EN60079-11:2012.
BAS02ATEX1290X Issue 8	17 April 2013	To permit the introduction of an alternative XP95 Manual Call Point, defined by drawing 55200-940CS, which additionally carries the following marking:  <b>⊕ II 1D Ex ia IIIC T135°C Da (<math>-20^{\circ}\text{C} \leq \text{Ta} \leq +60^{\circ}\text{C}</math>)</b>  The input parameters for all variants are identical to the original parameters and are as stated above.  To confirm that a special condition of safe use applies to both designs of Manual Call Points; this states that the enclosure may constitute a potential electrostatic ignition hazard and must not be rubbed or cleaned with a dry cloth or mounted in dust laden airflow.  This issue is supported by test report GB/BAS/ExTR13.0090/00. Project File No. 12/1015.
BAS02ATEX1290X Issue 9	26 November 2013	To permit minor drawing changes that do not affect the original assessment.  This issue is supported by test report GB/BAS/ExTR13.0293/00. Project File No. 13/0986.

Certificate No.	Date	Comments
BAS02ATEX1290X Issue 10	23 February 2015	To permit minor label changes. This issue is supported by test report GB/BAS/ExTR15.0059/00. Project File No. 14/0988.
BAS02ATEX1290X Issue 11	14 September 2017	To permit minor drawing changes that do not affect the original assessment and to confirm that the equipment meets the requirements of EN 60079-0:2012+A11:2013. This issue is supported by test report GB/BAS/ExTR17.0244/00. Project File No. 17/0348.
For drawings applicable to each issue, see original of that issue.		



1 **EU - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 2014/34/EU**

3 EU - Type Examination Certificate **BAS02ATEX1290X – Issue 12**  
Number:

3.1 In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

4 Product: **XP95 Intrinsically Safe Manual Call Point**

5 Manufacturer: **Apollo Fire Detectors Limited**

6 Address: **36 Brookside Road, Havant, Hampshire, PO9 1JR**

7 This re-issued certificate extends EC Type Examination Certificate No. **BAS02ATEX1290X** to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 SGS Fimko Oy, Notified Body number 0598, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

8.1 The original certificate was issued by The Electrical Equipment Certification Service (UK Notified Body 0600). It, and any supplements previously issued by SGS Baseefa Ltd (UK Notified Body 1180) have been transferred to the supervision of SGS Fimko Oy (EU Notified Body 0598). The original certificate number is retained.

The examination and test results are recorded in confidential Report No. **See Certificate History**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN IEC 60079-0:2018 EN 60079-11:2012**

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign “X” is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following:

**See equipment schedule**

SGS Fimko Oy Customer Reference No. 0073

Project File No. **20/0145**

This document is issued by the Company subject to their General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company’s findings at the time of their intervention only and within the limits of Client’s instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGS Fimko Oy**

Takomotie 8  
FI-00380 Helsinki, Finland  
Telephone +358 (0)9 696 361  
e-mail [sgs.fimko@sgs.com](mailto:sgs.fimko@sgs.com)  
web site [www.sgs.fi](http://www.sgs.fi)

Business ID 0978538-5 Member of the SGS Group (SGA SA)



D BREARLEY  
Certification  
Manager

**R S SINCLAIR**  
Authorised Signatory for SGS Fimko Oy

13

## Schedule

14



Certificate Number BAS02ATEX1290X – Issue 12

### 15 Description of Product

The XP95 Intrinsically Safe Manual Call Point is designed to initiate an alarm on a fire detector system.

The Manual Call Point comprises an electronics circuit mounted on a single printed circuit board, an LED and a switch located in a plastic enclosure. Connections to external circuits are made to terminal block TB1 located on the PCB via a cable entry gland.

The equipment is coded:

 II 1G Ex ia IIC T5 Ga (-20°C ≤ Ta ≤ +45°C) or Ex ia IIC T4 Ga (-20°C ≤ Ta ≤ 60°C) or  
 II 1D Ex ia IIIC T135°C Da (-20°C ≤ Ta ≤ +60°C)

### Input Parameters (all versions)

#### Terminal Block TB1:

$U_i = 28V$        $C_i = 0$

$I_i = 93.3mA$        $L_i = 0$

$P_i = 0.67W$

### 16 Report Number

See Certificate History

### 17 Specific Conditions of Use

1. The enclosure may constitute a potential electrostatic ignition hazard and must not be rubbed or cleaned with a dry cloth or mounted in dust laden airflow.

### 18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product:

Clause	Subject	Compliance
1.4.1	External effects	User/Installer responsibility
1.4.2	Aggressive substances, etc.	User/Installer responsibility

### 19 Drawings and Documents

New drawings submitted for this issue of certificate.

Number	Sheet	Issue	Date	Description
39117-518	1 of 1	6	May 19	XP95 I.S. Manual Call Point Certification Plate Label
55100-940CS	1 – 3	9	May 19	XP95 Intrinsically Safe Manual Call Point
55200-940CS	1 – 3	3	May 19	XP95 Intrinsically Safe Manual Call Point
55000-960-967INCL	1 of 1	20	May 19	XP95 Intrinsically Safe Waterproof Manual Call Point General Assembly

Current drawings also associated with this certificate.

Number	Sheet	Issue	Date	Description
39117-713	1 of 1	2	Jul 11	XP95 I.S. Manual Call Point Certification Label
43781-263	1 of 1	5	Jul 11	XP95 Intrinsically Safe Manual Call Point PCB Assembly
55000-960-967INCL	1 of 1	4	Jul 11	XP95 Intrinsically Safe Waterproof Manual Call Point General Assembly
55000-970-973INCL	1 of 1	3	Jul 11	Push Button Waterproof Manual Call Point General Assembly
55100-940CS	1 – 3	7	Nov 14	XP95 Intrinsically Safe Manual Call Point
55200-940CS	1 – 3	2	Nov 14	XP95 Intrinsically Safe Manual Call Point

## 20 Certificate History

Certificate No.	Date	Comments
BAS02ATEX1290	25 September 2002	The release of the prime certificate. The associated test and assessment against the requirements of EN50014:1997 + Amds 1 & 2, EN50020:2002 and EN50284:1999 is documented in Test Report No. 02(C)0238.
BAS02ATEX1290/1	6 August 2003	To permit a minor variation to the identification label. Intrinsic Safety is not affected.
BAS02ATEX1290/2	18 January 2008	To permit the use of a new plastic enclosure which does not affect the original assessment. A new single drawing replaces the older separate drawings.
BAS02ATEX1290/3	11 February 2009	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290/4	12 January 2010	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290 Issue 5	11 July 2011	To permit minor drawing changes that do not affect the original assessment and a change to the T5 ambient temperature range. The range is now $-20^{\circ}\text{C} \leq T_a \leq +45^{\circ}\text{C}$ .  This issue of the certificate also incorporates previously issued primary & supplementary certificates into one certificate and, following minor changes to the PCBs, confirms the current design meets the requirements of EN60079-0:2009 and EN60079-11:2007.
BAS02ATEX1290 Issue 6	30 August 2012	To permit minor drawing changes that do not affect the original assessment and to correct the input parameters.
BAS02ATEX1290 Issue 7	16 November 2012	To permit minor drawing changes that do not affect the original assessment and to confirm that the current design meets the requirements of EN60079-0:2012 and EN60079-11:2012.
BAS02ATEX1290X Issue 8	17 April 2013	To permit the introduction of an alternative XP95 Manual Call Point, defined by drawing 55200-940CS, which additionally carries the following marking:  <b>⊕ II 1D Ex ia IIC T135°C Da (-20°C ≤ Ta ≤ +60°C)</b>  The input parameters for all variants are identical to the original parameters and are as stated above.  To confirm that a special condition of safe use applies to both designs of Manual Call Points; this states that the enclosure may constitute a

<b>Certificate No.</b>	<b>Date</b>	<b>Comments</b>
		potential electrostatic ignition hazard and must not be rubbed or cleaned with a dry cloth or mounted in dust laden airflow.  This issue is supported by test report GB/BAS/ExTR13.0090/00. Project File No. 12/1015.
BAS02ATEX1290X Issue 9	3 December 2013	To permit minor drawing changes that do not affect the original assessment.  This issue is supported by test report GB/BAS/ExTR13.0293/00. Project File No. 13/0986.
BAS02ATEX1290X Issue 10	23 February 2015	To permit minor label changes. Test Report GB/BAS/ExTR15.0059/00. Project File No. 14/0988.
BAS02ATEX1290X Issue 11	14 September 2017	To permit minor drawing changes that do not affect the original assessment and to confirm that the equipment meets the requirements of EN 60079-0:2012+A11:2013.  This issue is supported by test report GB/BAS/ExTR17.0244/00. Project File No. 17/0348.
BAS02ATEX1290X Issue 12	19 March 2020	To permit minor electrical changes forming an alternative PCB and to confirm that the equipment meets the requirements of EN IEC 60079-0:2018. Test Report GB/BAS/ExTR20.0054/00. Project File No. 20/0145
For drawings applicable to each issue, see original of that issue.		

1 **EU - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 2014/34/EU**

3 EU - Type Examination Certificate **BAS02ATEX1290X – Issue 13**  
Number:

3.1 In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

4 Product: **XP95 Intrinsically Safe Manual Call Point**

5 Manufacturer: **Apollo Fire Detectors Limited**

6 Address: **36 Brookside Road, Havant, Hampshire, PO9 1JR**

7 This re-issued certificate extends EC Type Examination Certificate No. **BAS02ATEX1290X** to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 SGS Fimko Oy, Notified Body number 0598, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

8.1 The original certificate was issued by The Electrical Equipment Certification Service (UK Notified Body 0600). It, and any supplements previously issued by SGS Baseefa Ltd (UK Notified Body 1180) have been transferred to the supervision of SGS Fimko Oy (EU Notified Body 0598). The original certificate number is retained.

The examination and test results are recorded in confidential Report No. **See Certificate History**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN IEC 60079-0:2018 EN 60079-11:2012**

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign “X” is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following:

**See Schedule**

SGS Fimko Oy Customer Reference No. **0073**

Project File No. **20/0640**

This document is issued by the Company subject to their General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company’s findings at the time of their intervention only and within the limits of Client’s instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGS Fimko Oy**

Takomotie 8  
FI-00380 Helsinki, Finland  
Telephone +358 (0)9 696 361  
e-mail [sgs.fimko@sgs.com](mailto:sgs.fimko@sgs.com)  
web site [www.sgs.fi](http://www.sgs.fi)

Business ID 0978538-5 Member of the SGS Group (SGA SA)



**R S SINCLAIR**  
Authorised Signatory for SGS Fimko Oy

13

## Schedule

14

Certificate Number BAS02ATEX1290X – Issue 13

### 15 Description of Product

The XP95 Intrinsically Safe Manual Call Point is designed to initiate an alarm on a fire detector system.

The Manual Call Point comprises an electronics circuit mounted on a single printed circuit board, an LED and a switch located in a plastic enclosure. Connections to external circuits are made to terminal block TB1 located on the PCB via a cable entry gland.

The equipment is coded:

⊕ Ex II 1G Ex ia IIC T5 Ga (-20°C ≤ Ta ≤ +45°C) or Ex ia IIC T4 Ga (-20°C ≤ Ta ≤ 60°C) or  
⊕ Ex II 1D Ex ia IIC T135°C Da (-20°C ≤ Ta ≤ +60°C)

### Input Parameters (all versions)

#### Terminal Block TB1:

$$U_i = 28V \quad C_i = 0$$

$$I_i = 93.3mA \quad L_i = 0$$

$$P_i = 0.67W$$

### 16 Report Number

See Certificate History

### 17 Specific Conditions of Use

1. The enclosure may constitute a potential electrostatic ignition hazard and must not be rubbed or cleaned with a dry cloth or mounted in dust laden airflow.

### 18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product:

Clause	Subject	Compliance
1.4.1	External effects	User/Installer responsibility
1.4.2	Aggressive substances, etc.	User/Installer responsibility

### 19 Drawings and Documents

New drawings submitted for this issue of certificate.

Number	Sheet	Issue	Date	Description
55100-940CS	1 to 3	10	Dec 20	XP95 Intrinsically Safe Manual Call Point

Current drawings also associated with this certificate.

Number	Sheet	Issue	Date	Description
39117-518	1 of 1	6	May 19	XP95 I.S. Manual Call Point Certification Plate Label
39117-713	1 of 1	2	Jul 11	XP95 I.S. Manual Call Point Certification Label

Number	Sheet	Issue	Date	Description
43781-263	1 of 1	5	Jul 11	XP95 Intrinsically Safe Manual Call Point PCB Assembly
55000-960-967INCL	1 of 1	20	May 19	XP95 Intrinsically Safe Waterproof Manual Call Point General Assembly
55000-970-973INCL	1 of 1	3	Jul 11	Push Button Waterproof Manual Call Point General Assembly
55200-940CS	1 – 3	3	May 19	XP95 Intrinsically Safe Manual Call Point

The drawings are common to, and held with, IECEx BAS 12.0091X Iss 6.

## 20 Certificate History

Certificate No.	Date	Comments
BAS02ATEX1290	25 September 2002	The release of the prime certificate. The associated test and assessment against the requirements of EN50014:1997 + Amds 1 & 2, EN50020:2002 and EN50284:1999 is documented in Test Report No. 02(C)0238.
BAS02ATEX1290/1	6 August 2003	To permit a minor variation to the identification label. Intrinsic Safety is not affected.
BAS02ATEX1290/2	18 January 2008	To permit the use of a new plastic enclosure which does not affect the original assessment. A new single drawing replaces the older separate drawings.
BAS02ATEX1290/3	11 February 2009	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290/4	12 January 2010	To permit minor drawing changes that do not affect the original assessment.
BAS02ATEX1290 Issue 5	11 July 2011	To permit minor drawing changes that do not affect the original assessment and a change to the T5 ambient temperature range. The range is now $-20^{\circ}\text{C} \leq T_a \leq +45^{\circ}\text{C}$ .  This issue of the certificate also incorporates previously issued primary & supplementary certificates into one certificate and, following minor changes to the PCBs, confirms the current design meets the requirements of EN60079-0:2009 and EN60079-11:2007.
BAS02ATEX1290 Issue 6	30 August 2012	To permit minor drawing changes that do not affect the original assessment and to correct the input parameters.
BAS02ATEX1290 Issue 7	16 November 2012	To permit minor drawing changes that do not affect the original assessment and to confirm that the current design meets the requirements of EN60079-0:2012 and EN60079-11:2012.
BAS02ATEX1290X Issue 8	17 April 2013	To permit the introduction of an alternative XP95 Manual Call Point, defined by drawing 55200-940CS, which additionally carries the following marking:  <b>Ⓔ II 1D Ex ia IIC T135°C Da (-20°C ≤ Ta ≤ +60°C)</b>  The input parameters for all variants are identical to the original parameters and are as stated above.  To confirm that a special condition of safe use applies to both designs of Manual Call Points; this states that the enclosure may constitute a potential electrostatic ignition hazard and must not be rubbed or cleaned with a dry cloth or mounted in dust laden airflow.

<b>Certificate No.</b>	<b>Date</b>	<b>Comments</b>
		This issue is supported by test report GB/BAS/ExTR13.0090/00. Project File No. 12/1015.
BAS02ATEX1290X Issue 9	3 December 2013	To permit minor drawing changes that do not affect the original assessment. This issue is supported by test report GB/BAS/ExTR13.0293/00. Project File No. 13/0986.
BAS02ATEX1290X Issue 10	23 February 2015	To permit minor label changes. Test Report GB/BAS/ExTR15.0059/00. Project File No. 14/0988.
BAS02ATEX1290X Issue 11	14 September 2017	To permit minor drawing changes that do not affect the original assessment and to confirm that the equipment meets the requirements of EN 60079-0:2012+A11:2013. This issue is supported by test report GB/BAS/ExTR17.0244/00. Project File No. 17/0348.
BAS02ATEX1290X Issue 12	19 March 2020	To permit minor electrical changes forming an alternative PCB and to confirm that the equipment meets the requirements of EN IEC 60079-0:2018. Test Report GB/BAS/ExTR20.0054/00. Project File No. 20/0145
BAS02ATEX1290X Issue 13	8 February 2021	To permit minor drawing changes. Test Report GB/BAS/ExTR21.0023/00. Project File No. 20/0640
For drawings applicable to each issue, see original of that issue.		