Certificate No.: 2531-CPR-CSP11122





CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

45681-276 Analogue addressable Type A Ancillary detector base sounder for use in fire detection and alarm systems

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Apollo Fire Detectors Ltd. 36 Brookside Road, Havant, Hampshire, GB-P09 1JR United Kingdom

and produced in the manufacturing plant:

Echo Electronics Company Ltd/Yi Gao Tech Electronics (Shenzhen) Co. Ltd 2/F and 3/F, 301 Complex Building, 11 Jiayi Industrial Park Guixiang Community, Guanlan Street, Longhua District Shenzhen, China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-3:2001/A1:2002/A2:2006 : Fire detection and fire alarm systems - Part 3: Fire alarm devices - Sounders

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: 2021-07-26.

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

(This certificate supersedes the previous version of this certificate issued 2019-10-28)

This certificate was first issued 2019-10-28.

Merete Poulsen Responsible for evaluation Thomas Anthony Wilson Responsible for certification decision



Certificate No.: 2531-CPR-CSP11122





Annex 1

EXTENT

Type

45681-276 Analogue Addressable Type A Ancillary Detector Base Sounder for use in Fire Detection and Alarm Systems

Sounder Tones:

990Hz (0.5s) / 630Hz (0.5s) Alternating tone – wifi variable volume control

Performance

Essential characteristics	Clauses in EN 54-3:2001	Performance
Performance under fire conditions	4.2, 4.3, 5.2, 5.3	Pass
Operational reliability	4.4, 4.5, 4.6, 5.4, C4	Pass
Durability of operational reliability	5.5, 5.6, 5.7, 5.8, 5.9	Pass
and response delay; temperature		
resistance		
Durability of operational reliability;	5.8, 5.9, 5.10	Pass
humidity resistance		
Durability of operational reliability;	5.11	Pass
corrosion resistance		
Durability of operational reliability;	5.12 to 5.15	Pass
vibration resistance		
Durability of operational reliability;	5.16	Pass
electrical stability		
Durability of operational reliability;	5.17	Pass
resistance to ingress		

^{5.6} and 5.10 applies only to outdoor sounders or outdoor voice sounders.



^{5.16} applies only to sounders or voice sounders with active electronic components

Certificate No.: 2531-CPR-CSP11122





Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
BRE	TE 222021-1	21 September 2006

TECHNICAL BASIS

	File Number			Title	
45681-276		Build Standa	ard		

