Certificate No.: 2531-CPR-CSP11170



## **CERTIFICATE OF CONSTANCY OF PERFORMANCE**

Issued by DBI Certification, notified body No. 2531.

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

45681-331 Addressable Type A Sounder Beacon Base for use in fire detection and alarm systems

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Apollo Fire Detectors Ltd. 36 Brookside Road Havant, Hampshire, P09 1JR United Kingdom

and produced in the manufacturing plant:

Apollo Fire Detectors Ltd. 36 Brookside Road Havant, Hampshire, P09 1JR United Kingdom

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

EN 54-3:2001/A1:2002/A2:2006 : Fire detection and fire alarm systems - Part 3: Fire alarm devices - Sounders

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

## CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2019-11-28 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Chris Ellis

Responsible for evaluation

Date of issue: 2023-10-26

(This certificate supersedes the previous version of this certificate issued 2019-11-28)

Steen Nilsson

Responsible for certification decision



# Certificate No.: 2531-CPR-CSP11170



#### Annex 1

## **EXTENT**

# Type:

45681-331 Addressable Type A Sounder Beacon Base for use in fire detection and alarm systems

#### **Sounder Tones:**

Alert. High range- variable from 75dB(A) to (91dB(A), 0Hz (1s), 825Hz(1s)Evacuate. High range- variable from 75dB(A) to (91dB(A), 550Hz(0.5s), 825Hz(0.5s)

# **Performance**

Essential characteristics	Clauses in EN 54-3:2001	Performance
Performance under fire conditions	4.2, 4.3, 5.2, 5.3	Pass
Operational reliability	4.4, 4.5, 4.6, 5.4, C4	Pass
Durability of operational reliability and response delay; temperature	5.5, 5.6, 5.7, 5.8, 5.9	Pass
resistance		
Durability of operational reliability; humidity resistance	5.8, 5.9, 5.10	Pass
Durability of operational reliability; corrosion resistance	5.11	Pass
Durability of operational reliability; vibration resistance	5.12 to 5.15	Pass
Durability of operational reliability; electrical stability	5.16	Pass
Durability of operational reliability; resistance to ingress	5.17	Pass

<sup>5.6</sup> and 5.10 applies only to outdoor sounders or outdoor voice sounders.



<sup>5.16</sup> applies only to sounders or voice sounders with active electronic components

# Certificate No.: 2531-CPR-CSP11170



# Annex 2

# **TEST DOCUMENTATION**

Accredited Laboratory	Report no.	Date
BRE	TE 225322/2	2006-09-19
BRE	TE-P110938-1001 Issue: 1	2019-03-25

## **TECHNICAL BASIS**

File Number	Title
45681-331	Build Standard





