

**CERTIFICATE OF CONSTANCY OF PERFORMANCE**

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

**55000-131 Series 65 Conventional Class CR Heat Detector with Flashing LED**

The product fulfils the essential characteristic:

**See Annex 1**

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

**Apollo Fire Detectors Ltd.  
36 Brookside Road,  
GB-P09 1JR Havant, Hampshire  
United Kingdom**

and produced in the manufacturing plant:

**Apollo Fire Detectors Ltd.  
36 Brookside Road,  
GB-P09 1JR Havant, Hampshire  
United Kingdom**

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

**EN 54-5:2017/A1:2018** : **Fire detection and fire alarm systems – Part 5: Heat detectors - point heat detectors**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.**

This certificate was first issued on 2019-10-09 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: **2022-06-10**.

(This certificate supersedes the previous version of this certificate issued 2019-10-09)



Merete Poulsen  
Responsible for evaluation



Steen Nilsson  
Responsible for certification decision

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

Annex 1

**EXTENT**

**Model Reference:**

55000-131 Series 65 Conventional Class CR Heat Detector with Flashing LED

**Bases:**

- 45681-200 Series 60/65 Mounting Base
- 45681-201 Series 60/65 Diode Mounting Base
- 45681-245 Series 65 Relay Mounting Base
- 45681-246 Series 65 Auxiliary Mounting Base
- 45681-247 Series 65 EOL 12 Volt Mounting Base
- 45681-248 Series 65 EOL 24 Volt Mounting Base

**Note:**

1. Meets the requirements of EN54: Part 5 at Class CR

**Description:**

Class C Adressable Heat Detector intend for use in fire detection and fire alarm systems intalled in and around buldings. With additional test for Suffix R detectors.

**Operating Voltage:**

9 to 33 V DC

**Heat Response Catergy:**

\*For detector categories with the suffix S or R, additional requirements are needed see 4.4.1 or 4.4.2

Table 1

Detector Category (Heat Class):	Typical Application Temperature	Maximum Application Temperature °C	Minimum Static Response Temperature °C	Maximum Static Response Temperature °C
CR	55	80	84	100

Table 2- Response time limits

Rate of rise of air temperature K min <sup>-1</sup>	Cat CR			
	Lower limit		Uper limit	
	Min	S	Min	S
1	29	0	46	0
3	7	13	16	0
5	4	9	10	0
10	2	0	5	30
20	1	30	3	13
30		40	2	25

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

Performance				
Essential characteristics	Clauses in EN 54-5:2017/ A1:2018	Regulatory classes	Performance	
<b>Operational reliability:</b>				
Position of heat sensitive element	4.2.1	CR	The heat sensitive element(s) or at least part of it, except elements with auxiliary functions (e.g.characteristic correctors), are a distance $\geq 15\text{mm}$ from the mounting surface of the point heat detector.	
Individual alarm indication	4.2.2		Category CR The heat detector is provided with an integral red visual indicator and can remain identified until the alarm is reset. The visual indicator is visible from a distance of 6 m directly below the point heat detector, in an ambient light intensity up to 500 lx.	
Connection of ancillary devices	4.2.3		Open or short circuit failures of connection to ancillary device do not prevent the correct operation of the detector	
Monitoring of detachable point heat detectors	4.2.4		A fault condition is signaled when the detector is removed from the mounting base.	
Manufacturer's adjustments	4.2.5		It is not possible to change the manufacture's settings except by special means (e.g. a special code or tool, or by breaking or remove a seal).	
Onsite adjustments of response behavior	4.2.6		The response behaviour cannot be modified.	
Software controlled detectors (when provided)	4.2.7		The detector does not incorporate any software controlled components.	
<b>Nominal activation conditions/Sensitivity:</b>				
Directional dependence	4.3.1		The response time of the point dectetor do not unduly depend on the direction of airflow around the point heat detector.	
Static response temperature	4.3.2		The response temperatures of the point heat detectors lie between the minimum and maximum static response temperatures, according to the category of the point heat detector in Table 1 above.	
Response times from typical application temperature	4.3.3		The response times of the point heat detector lie between the lower and upper response time limits for the appropriate point heat detector category in Table 2 above.	
Response times from 25 °C	4.3.4		The response time at 3 K min <sup>-1</sup> exceeds 7 min 13 s and the response time at 20 K min <sup>-1</sup> exceeds 1 min 0 s.	
Response times from high ambient temperature	4.3.5		No alarm or fault signal was given at high ambient temperatures appropriate to the anticipated service temepratures. CR 3 K min <sup>-1</sup> , Lower limit, 1 min 20 s and upper limit 16 m.	

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

		20 K min <sup>-1</sup> , Lower limit, 12 s and upper limit 3 m 13 s.				
Reproducibility	4.3.6	The response times of the point heat detectors lie between the lower and upper response time limits specified in Table 2 above.				
<b>Response delay (response time):</b>						
Additional test for suffix S point heat detectors	4.4.1	N/A				
Additional test for suffix R point heat detectors	4.4.2	Suffix R, the point heat detector maintains the response requirements of its category, in table 2 above, for high rates of rise of temperature from an initial temperature below the typical application temperature applicable to the category marked on it.				
		<table border="1"> <tr> <th>Point heat detector category</th> <th>Initial conditioning temperature °C</th> </tr> <tr> <td>CR</td> <td>35 ±2</td> </tr> </table>	Point heat detector category	Initial conditioning temperature °C	CR	35 ±2
Point heat detector category	Initial conditioning temperature °C					
CR	35 ±2					
<b>Tolerance to supply voltage:</b>						
Variation in supply parameters	4.5	The point heat detector does not unduly depend on variation in the supply parameters and lie between the lower and upper response time limits specified in Table 2 above.				
<b>Durability of nominal activation conditions/Sensitivity:</b>						
temperature resistance						
Cold (operational)	4.6.1.1	<p>No alarm or fault signal was given during the transition to the conditioning temperature or during the period at the condition temperature</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>CR: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>				
Dry heat (endurance)	4.6.1.2	<p>No fault signal was given on reconnection attributable to the endurance conditioning</p> <table border="1"> <tr> <th>Point heat detector category</th> <th>Conditioning Temperature °C</th> </tr> <tr> <td>CR</td> <td>80 ±2</td> </tr> </table> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>CR: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>	Point heat detector category	Conditioning Temperature °C	CR	80 ±2
Point heat detector category	Conditioning Temperature °C					
CR	80 ±2					

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

Humidity resistance		
Damp heat, cyclic (operational)	4.6.2.1	<p>No alarm or fault signal was given during the conditioning.</p> <p>Lower temperature: (25±3) °C Upper temperature: (40±2) °C</p> <p>Relative humidity: At lower temperature :≥ 95 % At upper temperature : (93 ±3) %</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>CR: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Damp heat, steady-state (endurance)	4.6.2.2	<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning Temperature : 40 ±2 °C Relative Humidity: 93 ±3 % Duration : 21 days</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>CR: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Corrosion resistance		
Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	4.6.3	<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning Temperature : 25 ±2 °C Relative Humidity: 93 ±3 % SO<sub>2</sub> concentration: 25 ±5 ppm (by volume) Duration : 21 days</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>CR: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Vibration resistance		
Shock (operational)	4.6.4.1	<p>No alarm or fault signal was given during the conditioning period or an additional 2 min.</p> <p>For specimen with a mass ≤ 4,75 kg :</p> <p>Shock pulse type: Half sine</p>

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

		<p>Pulse duration : 6 ms                  Peak acceleration: 10X (100-20M) ms<sup>-2</sup> (M is specimen mass in Kg)                  Number of directions: 6                  Pulses per direction: 3</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>CR: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Impact (operational)	4.6.4.2	<p>No alarm or fault signal was given during the conditioning period or an additional 2 min.</p> <p>Conditioning:                  Impact energy: 1,9 ±0,1 J                  Hammer velocity: 1,5 ±0,13 ms<sup>-1</sup>                  Number of impacts: 1</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>CR: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Vibration, sinusoidal (operational)	4.6.4.3	<p>No fault signal was given during the conditioning</p> <p>Conditioning:                  Frequency range: 10 to 150 Hz                  Acceleration amplitude: 5 ms<sup>-2</sup>(≈0,5 g<sub>n</sub>)                  Number of axes : 3                  Sweep rate: 1 octave min<sup>-1</sup>                  Number of sweep cycles: 1 per axis</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>CR: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Vibration, sinusoidal (endurance)	4.6.4.4	<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning:                  Frequency range: 10 to 150 Hz                  Acceleration amplitude: 10 ms<sup>-2</sup>(≈1,0 g<sub>n</sub>)                  Number of axes : 3                  Sweep rate: 1 octave min<sup>-1</sup>                  Number of sweep cycles: 20 per axis</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p>

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

		CR: 20 K min <sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6
Electrical stability EMC immunity (operational)	4.6.5	<p>Compliance in EN 50130-4:2011 and No fault signal was given during the conditioning.</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>CR: 20 K min<sup>-1</sup> was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>

Annex 2

**TEST DOCUMENTATION**

Accredited Laboratory	Report no.	Date
VdS	BMA 00018	2000-03-03
BRE	P122562-AB	2022-03-21

**TECHNICAL BASIS**

File Number	Title
55000-131	Build Standard
45681-200	Build Standard
45681-201	Build Standard
45681-245	Build Standard
45681-246	Build Standard
45681-247	Build Standard
45681-248	Build Standard

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.