

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

55000-182 XP95 analogue addressable DIN-rail sounder control unit for use in fire detection and alarm systems

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:
**Apollo Fire Detectors Ltd.,
36 Brookside Road,
GB-P09 1JR Havant, Hampshire
United Kingdom**

and produced in the manufacturing plant:
**Apollo Fire Detectors Ltd.,
36 Brookside Road,
GB-P09 1JR Havant, Hampshire
United Kingdom**

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

EN 54-18:2005 : **Fire detection and fire alarm systems - Part 18: Input/output devices**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2019-10-28 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: 2023-10-27

(This certificate supersedes the previous version of this certificate issued 2019-10-28)



Steen Nilsson
Responsible for evaluation



Merete Poulsen
Responsible for certification decision

Annex 1

EXTENT

Type: 55000-182 XP95 Analogue addressable DIN-rail sounder control unit for use in fire detection and alarm systems		
Performance		
Essential characteristics	Clauses in EN 54-18:2005	Performance
Response delay (response time)	5.2 1)	Pass
Performance under fire conditions	5.1.4	Pass
Operational reliability	5.1.4	Pass
Durability of operational reliability; temperature resistance	5.3, 5.4	Pass
Durability of operational reliability; vibration resistance	5.8 to 5.11	Pass
Durability of operational reliability; humidity resistance	5.5, 5.6	Pass
Durability of operational reliability; corrosion resistance	5.7	Pass
Durability of operational reliability; electrical stability	5.2, 5.12	Pass
1) Response delays may not be a function of the input/output device, in which case no assessment is made as part of this standard		

Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
BRE	TE 245499	2009-05-22
BRE	TE P124857 Revision 1	2023-09-22

TECHNICAL BASIS

File Number	Title
55000-182	Build Standard