

**CERTIFICATE OF CONSTANCY OF PERFORMANCE**

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

**55000-217 Series 65 conventional ionisation smoke detector for use in fire detection and alarm systems**

The product fulfils the essential characteristic:

**See Annex 1**

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

**Apollo Fire Detectors Ltd.  
36 Brookside Road  
Havant, Hampshire P09 1JR  
United Kingdom**

and produced in the manufacturing plant:

**Apollo Fire Detectors Ltd.  
36 Brookside Road  
Havant, Hampshire P09 1JR  
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-7:2018** : **Fire detection and fire alarm systems - part 7: Smoke detectors - Point smoke detectors that operate using scattered light, transmitted light or ionization**

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: **2022-02-10**

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

(This certificate supersedes the previous version of this certificate issued 2019-10-28)

This certificate was first issued 2019-10-28.



Steen Nilsson  
Responsible for evaluation



Allan Laursen  
Responsible for certification decision

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

**DBI Certification A/S**

Jernholmen 12, 2650 Hvidovre  
Tlf.: 36 34 90 90

E-mail: [info@dbicertification.dk](mailto:info@dbicertification.dk)  
[www.dbicertification.dk](http://www.dbicertification.dk)

 **DANAK**  
Prod. Reg. Nr. 7023

Version 2019-10-02  
Page **1** of **5**

Annex 1

**EXTENT**

**Type:**

55000-217 Series 65 conventional ionization smoke detector for use in fire detection and alarm systems

**Bases:**

- 45681-200 Series 60 mounting base
- 45681-201 Series 60 diode mounting base
- 45681-245 Series 65 relay mounting base
- 45681-246 Series 65 auxiliary mounting base
- 45681-247 Series 65 EOL 12 Volt mounting base
- 45681-248 Series 65 EOL 24 Volt mounting base

**Performance**

Essential characteristics	Clauses in EN 54-7:2018	Regulatory classes	Performance
<b>Operational reliability:</b>			
Individual alarm indication	4.2.1	None	The visual indicator(s) are visible from a distance of 6 m in an ambient light intensity up to 500 lx.
Connection of ancillary devices	4.2.2		Open or short circuit failures of connection to ancillary device did not prevent the correct operation of the detector
Monitoring of detachable detectors	4.2.3		A fault condition is signaled when the detector is removed from the mounting base.
Manufacturer's adjustments	4.2.4		It is not possible to adjust the detector settings without the use of a special tool to access into the detector or use of a code to enabling entry into the panel programming software.
On site adjustment of response behavior	4.2.5		The mode(s) of operation are adjustable from the Control and Indicating Equipment by use of a loop communication protocol. Access to enable mode changes is by software control of the protocol communication.
Protection against the ingress of foreign bodies	4.2.6		The chamber is designed so that a sphere of diameter (1,3±0,05) mm cannot pass into the sensor chamber.
Response to slowly developing fires	4.2.7		The provision of "drift compensation" (e.g. to compensate for sensor drift due to the build-up of dirt in the detector), does not lead to a significant reduction in the detectors sensitivity to slowly developing fires.
Software controlled detectors (when provided)	4.2.8		The software documentation and the software design

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

		complies with the requirements of EN 54-7:2018.
<b>Nominal activation conditions/sensitivity:</b>		
Repeatability	4.3.1	Ratio of response values $m_{max}:m_{min} \leq 1.6$ Lower response value, $m_{max}:m_{min} \geq 0.05 \text{ dB m}^{-1}$
Directional dependence	4.3.2	Ratio of response values $m_{max}:m_{min} \leq 1.6$ Lower response value, $m_{max}:m_{min} \geq 0.05 \text{ dB m}^{-1}$
Reproducibility	4.3.3	Ratio of response values $m_{max}:\bar{m} \leq 1.33$ Ratio of the response values $\bar{m}:m_{min} \leq 1.5$ Lower response value, $m_{min} \geq 0.05 \text{ dB m}^{-1}$
<b>Response delay (response time):</b>		
Air movement	4.4.1	Ratio is $> 0.0625$ and $< 1.60$ and the point smoke detector did not emit a fault nor alarm signal during the test with aerosol-free air
Dazzling	4.4.2	The specimen did not emit neither an alarm nor a fault signal and Ratio of response thresholds $m_{max}:m_{min} \leq 1.6$
<b>Tolerance to supply voltage:</b>		
Variation in supply parameters	4.5	Ratio of response values $m_{max}:m_{min} < 1.6$ Lower response value, $m_{min} \geq 0.05 \text{ dB m}^{-1}$
<b>Performance parameters under fire conditions:</b>		
Fire sensitivity	4.6	Evaluated as meeting the requirements of TF2 to TF5
<b>Durability of nominal activation conditions/Sensitivity:</b>		
temperature resistance		
Cold (operational)	4.7.1.1	The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{max}:m_{min} \leq 1.6$
Dry heat (operational)	4.7.1.2	The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{max}:m_{min} \leq 1.6$
Humidity resistance		
Damp heat, steady-state (operational)	4.7.2.1	The specimen did not emit neither an alarm nor a fault signal and ratio of response values $m_{max}:m_{min} \leq 1.6$
Damp heat, steady-state (endurance)	4.7.2.2	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{max}:m_{min} \leq 1.6$
Corrosion resistance		

Threshold

Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	4.7.3	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Vibration resistance		
Shock (operational)	4.7.4.1	No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Impact (operational)	4.7.4.2	No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Vibration, sinusoidal (operational)	4.7.4.3	No fault signal given from the specimen during the conditioning and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Vibration, sinusoidal (endurance)	4.7.4.4	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Electrical stability EMC immunity (operational)	4.7.5	No alarm or fault signal given during the conditioning and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
<ul style="list-style-type: none"> <li>a) Electrostatic discharge (operational)</li> <li>b) Radiated electromagnetic fields (operational)</li> <li>c) Conducted disturbances(operational)</li> <li>d) Fast transient bursts (operational)</li> <li>e) Slow high energy voltage surge (operational)</li> </ul>		

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

Annex 2

**TEST DOCUMENTATION**

Accredited Laboratory	Report no.	Date
VdS	BMA 00014	2000-02-11
BRE	AB-P118559	2022-01-22

**TECHNICAL BASIS**

File Number	Title
55000-217	Build Standard
45681-200	Build Standard
45681-201	Build Standard
45681-245	Build Standard
45681-246	Build Standard
45681-247	Build Standard
45681-248	Build Standard

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.