

## BRE Global Ireland

**Notified Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance

### 2831-CPR-F0608

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

**55000-742 Loop-Powered Type A VAD 8m (Red)**  
(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

**Apollo Fire Detectors Ltd**  
36 Brookside Road  
Havant  
Hampshire  
PO9 1JR  
United Kingdom

and produced in the manufacturing plant(s):

**Apollo Fire Detectors Ltd**  
36 Brookside Road  
Havant  
Hampshire  
PO9 1JR  
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 54-23:2010 - Visual alarm devices**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### **the constancy of performance of the construction product.**

This certificate was first issued on 23 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

Date of First Issue: 23 October 2019

Date of Issue: 16 April 2021

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie).

**BRE Global Ireland**

**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F0608**

**55000-742 Loop-Powered Type A VAD 8m (Red)**

1. The ceiling mounted VAD meets the requirements of EN 54-23:2010 for the following:

- Category rating C-3-8
- Synchronization
- Flash rate 0.5 Hz
- White LED
- Clear lens

2. Approved with XP95/Discovery 45681-210 mounting base and 45681-284 short circuit isolating base

**Bases:**

45681-210 XP95/Discovery mounting base

45681-284 XP95/Discovery short circuit isolating base



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 16 April 2021

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie).