

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

55000-797 XP95 Analogue Addressable DIN-Rail Mains Input/Output Unit

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

and produced in the manufacturing plant:

Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-18:2005 : **Fire detection and fire alarm systems - Part 18: Input/output devices**

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: **2019-10-22**.

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

This certificate was first issued 2019-10-22.



Merete Poulsen
Responsible for evaluation



Allan Laursen
Responsible for certification decision

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

DBI Certification A/S

Jernholmen 12, 2650 Hvidovre
Tlf.: 36 34 90 90

E-mail: info@dbicertification.dk
www.dbicertification.dk

Annex 1

EXTENT

Type:

55000-797 XP95 Analogue Addressable DIN-Rail Mains Input/Output Unit

Note:

To ensure compliance is maintained, this device shall be installed within an enclosure weighing greater than 4.75kg.

Performance

Essential characteristics	Clauses in EN 54-18:2005	Performance
Response delay (response time)	5.2 1)	Pass
Performance under fire conditions	5.1.4	Pass
Operational reliability	5.1.4	Pass
Durability of operational reliability; temperature resistance	5.3, 5.4	Pass
Durability of operational reliability; vibration resistance	5.8 to 5.11	Pass
Durability of operational reliability; humidity resistance	5.5, 5.6	Pass
Durability of operational reliability; corrosion resistance	5.7	Pass
Durability of operational reliability; electrical stability	5.2, 5.12	Pass
1) Response delays may not be a function of the input/output device, in which case no assessment is made as part of this standard		

The certificate shall be reproduced in extenso
 – extracts only with written permission from DBI Certification A/S.

Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
BRE	TE252733	11 August 2010

TECHNICAL BASIS

File Number	Title
55000-797	Build Standard

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

DBI Certification A/S

Jernholmen 12, 2650 Hvidovre
Tlf.: 36 34 90 90

E-mail: info@dbicertification.dk
www.dbicertification.dk