

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

55000-885 XP95 Analogue Addressable Multi-Sensor Detector

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

**Apollo Fire Detectors Ltd.
36 Brookside Road,
Havant, Hampshire GB-P09 1JR
United Kingdom**

and produced in the manufacturing plant:

**Apollo Fire Detectors Ltd.
36 Brookside Road,
Havant, Hampshire GB-P09 1JR
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-7:2018 : **Fire detection and fire alarm systems - part 7: Smoke detectors - Point smoke detectors that operate using scattered light, transmitted light or ionization**

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: 2020-07-01.

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

(This certificate supersedes the previous version of this certificate issued 2019-10-09)

This certificate was first issued 2019-10-09.



Thomas Anthony Wilson
Responsible for evaluation



Merete Poulsen
Responsible for certification decision

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Annex 1

EXTENT

Type:

55000-885 XP95 Analogue Addressable Multi-Sensor Detector

Variant:

55000-885LIM (branded as Limotec)

Bases:

45681-209 XP95/Discovery standard deep mounting base

45681-210 XP95 mounting base

Performance

Essential characteristics	Clauses in EN 54-7:2018	Regulatory classes	Performance
Operational reliability:			
Individual alarm indication	4.2.1	None	The visual indicator(s) are visible from a distance of 6 m in an ambient light intensity up to 500 lx.
Connection of ancillary devices	4.2.2		Open or short circuit failures of connection to ancillary device did not prevent the correct operation of the detector
Monitoring of detachable detectors	4.2.3		A fault condition is signaled when the detector is removed from the mounting base.
Manufacturer's adjustments	4.2.4		It is not possible to adjust the detector settings without the use of a special tool to access into the detector or use of a code to enabling entry into the panel programming software.
On site adjustment of response behavior	4.2.5		The mode(s) of operation are adjustable from the Control and Indicating Equipment by use of a loop communication protocol. Access to enable mode changes is by software control of the protocol communication.
Protection against the ingress of foreign bodies	4.2.6		The chamber is designed so that a sphere of diameter (1,3±0,05) mm cannot pass into the sensor chamber.

The certificate shall be reproduced in extenso
 – extracts only with written permission from DBI Certification A/S.

Response to slowly developing fires	4.2.7		The provision of "drift compensation" (e.g. to compensate for sensor drift due to the build-up of dirt in the detector), does not lead to a significant reduction in the detectors sensitivity to slowly developing fires.	
Software controlled detectors (when provided)	4.2.8		The software documentation and the software design complies with the requirements of EN 54-7:2018.	
Nominal activation conditions/sensitivity:				
Repeatability	4.3.1	Threshold	Ratio of response values $m_{max}:m_{min} \leq 1.6$ Lower response value, $m_{max}:m_{min} \geq 0.05 \text{ dB m}^{-1}$	
Directional dependence	4.3.2		Ratio of response values $m_{max}:m_{min} \leq 1.6$ Lower response value, $m_{max}:m_{min} \geq 0.05 \text{ dB m}^{-1}$	
Reproducibility	4.3.3		Ratio of response values $m_{max}:\bar{m} \leq 1.33$ Ratio of the response values $\bar{m}:m_{min} \leq 1.5$ Lower response value, $m_{min} \geq 0.05 \text{ dB m}^{-1}$	
Response delay (response time):				
Air movement	4.4.1		Ratio is > 0.0625 and < 1.60 and the point smoke detector did not emit a fault nor alarm signal during the test with aerosol-free air	
Dazzling	4.4.2		The specimen did not emit neither an alarm nor a fault signal and Ratio of response thresholds $m_{max}:m_{min} \leq 1.6$	
Tolerance to supply voltage:				
Variation in supply parameters	4.5		Ratio of response values $m_{max}:m_{min} < 1.6$ Lower response value, $m_{min} \geq 0.05 \text{ dB m}^{-1}$	
Performance parameters under fire conditions:				
Fire sensitivity	4.6		Evaluated as meeting the requirements of TF2 toTF5	
Durability of nominal activation conditions/Sensitivity:				
temperature resistance				
Cold (operational)	4.7.1.1	The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{max}:m_{min} \leq 1.6$		

The certificate shall be reproduced in extenso
 – extracts only with written permission from DBI Certification A/S.

Dry heat (operational)	4.7.1.2	The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Humidity resistance		
Damp heat, steady-state (operational)	4.7.2.1	The specimen did not emit neither an alarm nor a fault signal and ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Damp heat, steady-state (endurance)	4.7.2.2	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Corrosion resistance		
Sulphur dioxide (SO ₂) corrosion (endurance)	4.7.3	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Vibration resistance		
Shock (operational)	4.7.4.1	No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Impact (operational)	4.7.4.2	No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Vibration, sinusoidal (operational)	4.7.4.3	No fault signal given from the specimen during the conditioning and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Vibration, sinusoidal (endurance)	4.7.4.4	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
Electrical stability EMC immunity (operational)	4.7.5	No alarm or fault signal given during the conditioning and Ratio of response values $m_{max} \cdot m_{min} \leq 1.6$
a) Electrostatic discharge (operational)		
b) Radiated electromagnetic fields (operational)		
c) Conducted disturbances(operational)		
d) Fast transient bursts (operational)		
e) Slow high energy voltage surge (operational)		

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
BRE	TE 209309	23 May 2002
BRE	TE 238037	28 January 2008
BRE	TE 238037-SW	29 January 2008
BRE	TE301792 Issue: 1	09 June 2015
LPC	TE 90373	29 December 1998
LPC	TE 93009	12 October 1999
BRE	TE-P117352 Issue: 1	09 June 2020

TECHNICAL BASIS

File Number	Title
55000-885	Build Standard
45681-209	Build Standard
45681-210	Build Standard

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.