

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland T: +353 (0) 18824344

E: <u>enquiries@breglobalireland.ie</u> www.breglobalireland.ie

Certificate of constancy of performance 2831-CPR-F1494

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

58000-005 Discovery Type B Intelligent Open Area Sound Beacon (Red)

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade

mark of:

Apollo Fire Detectors Limited 36 Brookside Road

Havant Hampshire PO9 1JR

United Kingdom

and produced in the manufacturing plant(s):

Apollo Fire Detectors Limited

36 Brookside Road

Havant Hampshire PO9 1JR

United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006 - Sounders

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 23 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Date of First Issue: 23 October 2019

E Mattie-Suleiman, Certification Engineer Date of Issue: 23 October 2019

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BF1938i Rev.1.0 Page 1 of 2 © BRE Global Assurance (Ireland) Limited, 2019



BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland

T: +353 (0) 18824344 E: enquiries@breglobalireland.ie www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F1494

58000-005 Discovery Type B Intelligent Open Area Sound Beacon (Red)

Bases:

45681-517 Enhanced deep isolating base (White) 45681-518 Enhanced deep isolating base (Red)

Notes:

1. Meets the requirements of EN 54-3:2001 at the following tones:

T1- Apollo Evacuation 558Hz,0.5s/840Hz,0.5s

T3- Dutch Slow Whoop 500-1200Hz in 3.5s, 0.5s off

T4- German DIN1200-500Hz over 1s

2. The Beacon function is not approved to EN 54-23

Variants:

58000-007 (White)

Date of First Issue: 23 October 2019

E Mattie-Suleiman, Certification Engineer, Date of issue: 23 October 2019

On behalf of BRE Global Assurance (Ireland) Limited Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.