

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00186

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): Analogue Addressable Waterproof Manual Call Point with Isolator
(refer to attached appendix for details and conditions)

**Placed on the market
under the name or trade mark of:** Apollo Fire Detectors Limited
36 Brookside Road
Havant, Hampshire, PO9 1JR
United Kingdom

**and produced in the
manufacturing plant(s):** Apollo Fire Detectors Limited (SG- 15556)
36 Brookside Road
Havant, Hampshire, PO9 1JR
United Kingdom

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

**EN 54-11:2001+A1:2005
EN 54-17:2005+AC:2007**


Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00186** on **2013-10-10** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

**Notified Body
0905**

Certification Manager: Dipl.-Ing. Roland Heine **Date Issue:** 2019-10-18

Signature:


92010



Issue: 1

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00186

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00186

The details and conditions of use for the Analogue Addressable Waterproof Manual Call Point with Isolator , placed on the market under the name or trade mark of:

Apollo Fire Detectors Limited
36 Brookside Road
Havant, Hampshire, PO9 1JR
United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN 54-11:2001+A1:2005 and EN 54-17:2005+AC:2007

Model	Manufacturing Location	Description
58200-951	SG-15556	Analogue Addressable Waterproof Manual Call Point with Isolator

Conditions of use:

Suitable for indoor and outdoor applications

General Notes:

1. Evaluated under Intertek project number 100975009, 101347460 and 103187049.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.