

**CERTIFICATE OF CONSTANCY OF PERFORMANCE**

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Orbis Class A1R Conventional Heat Detectors**

The product fulfils the essential characteristic:

**See Annex 1**

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

**Apollo Fire Detectors Ltd.  
36 Brookside Road  
Havant, Hampshire, GB-P09 1JR  
United Kingdom**

and produced in the manufacturing plant:

**Apollo Fire Detectors Ltd.  
36 Brookside Road  
Havant, Hampshire, GB-P09 1JR  
United Kingdom**

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

**EN 54-5:2017/A1:2018** : **Fire detection and fire alarm systems - Part 5: Heat detectors - point heat detectors**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.**

This certificate was first issued on 2019-10-09 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: **2022-06-30**

(This certificate supersedes the previous version of this certificate issued 2019-10-09)



Merete Poulsen  
Responsible for evaluation



Steen Nilsson  
Responsible for certification decision

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

Annex 1

**EXTENT**

**Model Reference:**

Orbis Class A1R Conventional Heat Detectors

**Variants:**

ORB-HT-11001-APO Orbis Class A1R Heat Detector with SensAlert and FasTest  
 ORB-HT-11013-APO Orbis Class A1R Heat Detector with Flashing LED, SensAlert and FasTest  
 OEX-HT-11037-APO Orbis Class A1R Heat Detector with Flashing LED and SensAlert  
 OEX-HT-11089-APO Orbis Class A1R Heat Detector with SensAlert

**Bases:**

OB: ORB-MB-00001-APO TimeSaver base  
 OL: ORB-MB-00002-APO TimeSaver base LX (without continuity checking link)  
 OD: ORB-DB-00003-APO TimeSaver diode base  
 OR: ORB-RB-10004-APO TimeSaver relay base  
 XL: ORB-MB-00012-APO & OEX-MB-00016-APO LX bases  
 EB: ORB-MB-00019-APO TimeSaver deep base

**Ancillary:**

ORB-BA-10008-APO Adaptor Base (to be used in conjunction with the following bases only: 45681-200 & 45681-201)

**Description:**

Class A1R Adressable Heat Detector intend for use in fire detection and fire alarm systems intalled in and around buldings. With additional test for Suffix R detectors.

**Operating Voltage:**

8.5 to 33 V DC

**Heat Response Category:**

\*For detector categories with the suffix S or R, additional requirements are needed see 4.4.1 or 4.4.2

**Table 1**

Detector Category (Heat Class):	Typical Application Temperature	Maximum Application Temperature °C	Minimum Static Response Temperature °C	Maximum Static Response Temperature °C
A1R	25	50	54	65

**Table 2- Response time limits**

Rate of rise of air temperature K min-1	Cat A1R			
	Lower limit		Uper limit	
	Min	S	Min	S
1	29	0	40	20
3	7	13	13	40
5	4	9	8	20
10	1	0	4	20
20		30	2	20
30		20	1	40

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

Performance				
Essential characteristics	Clauses in EN 54-5:2017/ A1:2018	Regulatory classes	Performance	
<b>Operational reliability:</b>				
Position of heat sensitive element	4.2.1	A1R	The heat sensitive element(s) or at least part of it, except elements with auxiliary functions (e.g. characteristic correctors), are a distance $\geq 15$ mm from the mounting surface of the point heat detector.	
Individual alarm indication	4.2.2		Category A1R The heat detector is provided with an integral red visual indicator and can remain identified until the alarm is reset. The visual indicator is visible from a distance of 6 m directly below the point heat detector, in an ambient light intensity up to 500 lx.	
Connection of ancillary devices	4.2.3		Open or short circuit failures of connection to ancillary device do not prevent the correct operation of the detector	
Monitoring of detachable point heat detectors	4.2.4		A fault condition is signaled when the detector is removed from the mounting base.	
Manufacturer's adjustments	4.2.5		It is not possible to change the manufacturer's settings except by special means (e.g. a special code or tool, or by breaking or remove a seal).	
Onsite adjustments of response behavior	4.2.6		N/A	
Software controlled detectors (when provided)	4.2.7		The software documentation and the software design complies supplied by the manufacturer with the requirements of this standard.	
<b>Nominal activation conditions/Sensitivity:</b>				
Directional dependence	4.3.1		The response time of the point detector do not unduly depend on the direction of airflow around the point heat detector.	
Static response temperature	4.3.2		The response temperatures of the point heat detectors lie between the minimum and maximum static response temperatures, according to the category of the point heat detector in Table 1 above.	
Response times from typical application temperature	4.3.3	The response times of the point heat detector lie between the lower and upper response time limits for the appropriate point heat detector category in Table 2 above.		
Response times from 25 °C	4.3.4	The response time at 3 K min <sup>-1</sup> exceeds 7 min 13 s and the response time at 20 K min <sup>-1</sup> exceeds 1 min 0 s.		
Response times from high ambient temperature	4.3.5	No alarm or fault signal was given at high ambient temperatures appropriate to the anticipated service temperatures.		
			A1R	

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

			3 K min <sup>-1</sup> , Lower limit, 1 min 20s and upper limit 13 m 40s. 20 K min <sup>-1</sup> , Lower limit, 12 s and upper limit 2 m 20 s.				
Reproducibility	4.3.6		The response times of the point heat detectors lie between the lower and upper response time limits specified in Table 2 above.				
<b>Response delay (response time):</b>							
Additional test for suffix S point heat detectors	4.4.1		N/A				
Additional test for suffix R point heat detectors	4.4.2		Suffix R, the point heat detector maintains the response requirements of its category, in table 2 above, for high rates of rise of temperature from an initial temperature below the typical application temperature applicable to the category marked on it.				
			<table border="1"> <thead> <tr> <th>Point heat detector category</th> <th>Initial conditioning temperature °C</th> </tr> </thead> <tbody> <tr> <td>A1R</td> <td>5 ±2</td> </tr> </tbody> </table>	Point heat detector category	Initial conditioning temperature °C	A1R	5 ±2
Point heat detector category	Initial conditioning temperature °C						
A1R	5 ±2						
<b>Tolerance to supply voltage:</b>							
Variation in supply parameters	4.5		The point heat detector does not unduly depend on variation in the supply parameters and lie between the lower and upper response time limits specified in Table 2 above.				
<b>Durability of nominal activation conditions/Sensitivity:</b>							
temperature resistance							
Cold (operational)	4.6.1.1		<p>No alarm or fault signal was given during the transition to the conditioning temperature or during the period at the condition temperature</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1R: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>				
Dry heat (endurance)	4.6.1.2		<p>No fault signal was given on reconnection attributable to the endurance conditioning</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1R: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>				
Humidity resistance							
Damp heat, cyclic (operational)	4.6.2.1		No alarm or fault signal was given during the conditioning.				

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

		<p>Lower temperature: (25±3) °C Upper temperature: (40±2) °C</p> <p>Relative humidity: At lower temperature :≥ 95 % At upper temperature : (93 ±3) %</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1R: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Damp heat, steady-state (endurance)	4.6.2.2	<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning Temperature : 40 ±2 °C Relative Humidity: 93 ±3 % Duration : 21 days</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1R: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Corrosion resistance		
Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	4.6.3	<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning Temperature : 25 ±2 °C Relative Humidity: 93 ±3 % SO<sub>2</sub> concentration: 25 ±5 ppm (by volume) Duration : 21 days</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1R: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Vibration resistance		
Shock (operational)	4.6.4.1	<p>No alarm or fault signal was given during the conditioning period or an additional 2 min.</p> <p>For specimen with a mass ≤ 4,75 kg :</p> <p>Shock pulse type: Half sine Pulse duration : 6 ms Peak acceleration: 10X (100-20M) ms<sup>-2</sup> (M is specimen mass in Kg) Number of directions: 6 Pulses per direction: 3</p>

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

		<p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1R: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Impact (operational)	4.6.4.2	<p>No alarm or fault signal was given during the conditioning period or an additional 2 min.</p> <p>Conditioning:                      Impact energy: 1,9 ±0,1 J                      Hammer velocity: 1,5 ±0,13 ms<sup>-1</sup>                      Number of impacts: 1</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1R: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Vibration, sinusoidal (operational)	4.6.4.3	<p>No fault signal was given during the conditioning</p> <p>Conditioning:                      Frequency range: 10 to 150 Hz                      Acceleration amplitude: 5 ms<sup>-2</sup>(≈0,5 g<sub>n</sub>)                      Number of axes : 3                      Sweep rate: 1 octave min<sup>-1</sup>                      Number of sweep cycles: 1 per axis</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1R: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Vibration, sinusoidal (endurance)	4.6.4.4	<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning:                      Frequency range: 10 to 150 Hz                      Acceleration amplitude: 10 ms<sup>-2</sup>(≈1,0 g<sub>n</sub>)                      Number of axes : 3                      Sweep rate: 1 octave min<sup>-1</sup>                      Number of sweep cycles: 20 per axis</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1R: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Electrical stability EMC immunity (operational)	4.6.5	<p>Compliance in EN 50130-4:2011 and No fault signal was given during the conditioning.</p>

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

			<p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1R: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
--	--	--	---

Annex 2

**TEST DOCUMENTATION**

Accredited Laboratory	Report no.	Date
BRE	211499	2004-01-05
BRE	TE 210363 SW	2003-05-01
BRE	TE 211499 SW/A	2004-12-22
BRE	TE 211499 SW/B	2004-03-29
BRE	TE P105641-1001 Issue: 1	2018-10-31

**TECHNICAL BASIS**

File Number	Title
400-HT-00001	Build Standard
400-HT-00002	Build Standard
ORB-MB-00001	Build Standard no. 300-MA-00003
ORB-MB-00002	Build Standard no. 300-MA-00006
ORB-DB-00003	Build Standard
ORB-RB-10004	Build Standard no. 400-RB-00007
ORB-MB-00012	Build Standard
ORB-MB-00019	Build Standard no. 300-MA-00012

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.