

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

SA5100-700 Soteria Analogue Addressable Class A1R Optical Smoke/Heat Detector with Short Circuit Isolator

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

Authorised Representative Address

Apollo Gesellschaft für Meldetechnologie MbH
Am Anger 31, 33332 Gütersloh, Germany

and produced in the manufacturing plant:

Apollo Fire Detectors Ltd.,
36 Brookside Road, GB-P09 1JR Havant, Hampshire, UK

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-5:2017/A1:2018 : **Fire detection and fire alarm systems - Part 5: Heat detectors - point heat detectors**
EN 54-17:2005 : **Fire detection and fire alarm systems - Part 17: Short-circuit isolators**
EN 54-7:2018 : **Fire detection and fire alarm systems - part 7: Smoke detectors - Point smoke detectors that operate using scattered light, transmitted light or ionization**

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: **2022-01-20**.

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

(This certificate supersedes the previous version of this certificate issued 2019-10-21)

This certificate was first issued 2019-10-21.



Allan Laursen
Responsible for evaluation



Merete Poulsen
Responsible for certification decision

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Annex 1

EXTENT

Type:

SA5100-700 Soteria Analogue Addressable Class A1R Optical Smoke/Heat Detector with Short Circuit Isolator

Variants:

SA5100-700LIM Optical Smoke/Heat Detector with Short Circuit Isolator

SA5100-760 Soteria Analogue Addressable Class A1R Optical Smoke/Heat Detector with Short Circuit Isolator (Black Colour)

Bases:

SA5000-200 Addressable XPERT 8 Mounting Base

45681-210 XP95 Mounting Base

Notes:

Certified at the following settings:

Mode 1: High sensitivity smoke detector with high heat enhancement

Mode 2: Standard smoke sensitivity only

Mode 3: Medium sensitivity smoke detector with medium heat enhancement

Mode 4: Low sensitivity smoke detector with high heat enhancement

Mode 5: Class A1R heat detector

Table 1

Detector Category (Heat Class):	Typical Application Temperature	Maximum Application Temperature °C	Minimum Static Response Temperature °C	Maximum Static Response Temperature °C
A1R	25	50	54	65

Choose relevant

Table 2- Response time limits

Rate of rise of air temperature K min ⁻¹	Cat A1R			
	Lower limit		Uper limit	
	Min	S	Min	S
1	29	0	40	20
3	7	13	13	40
5	4	9	8	20
10	1	0	4	20
20		30	2	20
30		20	1	40

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Performance				
Essential characteristics	Clauses in EN 54-5:2017/ A1:2018	Regulatory classes	Performance	
Operational reliability:				
Position of heat sensitive element	4.2.1	A1R	The heat sensitive element(s) or at least part of it, except elements with auxiliary functions (e.g. characteristic correctors), are a distance $\geq 15\text{mm}$ from the mounting surface of the point heat detector	
Individual alarm indication	4.2.2		Category A1R The heat detector is provided with an integral red visual indicator and can remain identified until the alarm is reset. The visual indicator is visible from a distance of 6 m directly below the point heat detector, in an ambient light intensity up to 500 lx.	
Connection of ancillary devices	4.2.3		Open or short circuit failures of connection to ancillary device do not prevent the correct operation of the detector	
Monitoring of detachable point heat detectors	4.2.4		A fault condition is signaled when the detector is removed from the mounting base.	
Manufacturer's adjustments	4.2.5		It is not possible to change the manufacturer's settings except by special means (e.g. a special code or tool, or by breaking or remove a seal).	
Onsite adjustments of response behavior	4.2.6		The detector is provided with a provision for an onsite adjustment of the response behavior and the manufacturer declares a corresponding class and adjustment setting: There are adjustable setting(s) which the manufacturer is not stating a corresponding category in accordance to this standard and are only accessible by the use of a code or special tool, and it is clearly marked on the point heat detector or in the associated data.	
Software controlled detectors (when provided)	4.2.7		The software documentation and the software design complies supplied by the manufacturer with the requirements of this standard.	
Nominal activation conditions/Sensitivity:				
Directional dependence	4.3.1		The response time of the point detector do not unduly depend on the direction of airflow around the point heat detector.	
Static response temperature	4.3.2		The response temperatures of the point heat detectors lie between the minimum and maximum static response temperatures, according to the category of the point heat detector in Table 1 above.	
Response times from typical application temperature	4.3.3	The response times of the point heat detector lie between the lower and upper response time limits for the appropriate point heat detector category in Table 2 above.		
Response times from 25 °C	4.3.4	The response time at 3 K min^{-1} exceeds 7 min 13 s and the response time at 20 K min^{-1} exceeds 1 min 0 s.		

The certificate shall be reproduced in extenso
 – extracts only with written permission from DBI Certification A/S.

Response times from high ambient temperature	4.3.5	No alarm or fault signal was given at high ambient temperatures appropriate to the anticipated service temperatures. A1 3 K min ⁻¹ , Lower limit, 1 min 20 s and upper limit 13 m 40 s. 20 K min ⁻¹ , Lower limit, 12 s and upper limit 2 m 20 s. All others 3 K min ⁻¹ , Lower limit, 1 min 20 s and upper limit 16 m. 20 K min ⁻¹ , Lower limit, 12 s and upper limit 3 m 13 s.				
Reproducibility	4.3.6	The response times of the point heat detectors lie between the lower and upper response time limits specified in Table 2 above.				
Response delay (response time):						
Additional test for suffix S point heat detectors	4.4.1	N/A				
Additional test for suffix R point heat detectors	4.4.2	Suffix R, the point heat detector maintains the response requirements of its category, in table 2 above, for high rates of rise of temperature from an initial temperature below the typical application temperature applicable to the category marked on it. <table border="1" data-bbox="885 913 1452 1019"> <tr> <td>Point heat detector category</td> <td>Initial conditioning temperature °C</td> </tr> <tr> <td>A1R</td> <td>5 ±2</td> </tr> </table>	Point heat detector category	Initial conditioning temperature °C	A1R	5 ±2
Point heat detector category	Initial conditioning temperature °C					
A1R	5 ±2					
Tolerance to supply voltage:						
Variation in supply parameters	4.5	The point heat detector does not unduly depend on variation in the supply parameters and lie between the lower and upper response time limits specified in Table 2 above.				
Durability of nominal activation conditions/ Sensitivity:						
temperature resistance						
Cold (operational)	4.6.1.1	No alarm or fault signal was given during the transition to the conditioning temperature or during the period at the condition temperature <u>For resettable point heat detector</u> Response time at 3 K min ⁻¹ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6. A1: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 All others: 20 K min ⁻¹ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6				
Dry heat (endurance)	4.6.1.2	No fault signal was given on reconnection attributable to the endurance conditioning <u>For resettable point heat detector</u> Response time at 3 K min ⁻¹ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6. A1: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 All others: 20 K min ⁻¹ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6				

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Humidity resistance			
Damp heat, cyclic (operational)	4.6.2.1		<p>No alarm or fault signal was given during the conditioning.</p> <p>Lower temperature: (25±3) °C Upper temperature: (40±2) °C</p> <p>Relative humidity: At lower temperature :≥ 95 % At upper temperature : (93 ±3) %</p> <p>For resettable point heat detector Response time at 3 K min⁻¹ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1: 20 K min⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 All others: 20 K min⁻¹ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Damp heat, steady-state (endurance)	4.6.2.2		<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning Temperature : 40 ±2 °C Relative Humidity: 93 ±3 % Duration : 21 days</p> <p>For resettable point heat detector Response time at 3 K min⁻¹ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1: 20 K min⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 All others: 20 K min⁻¹ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Corrosion resistance			
Sulphur dioxide (SO ₂) corrosion (endurance)	4.6.3		<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning Temperature : 25 ±2 °C Relative Humidity: 93 ±3 % SO₂ concentration: 25 ±5 ppm (by volume) Duration : 21 days</p> <p>For resettable point heat detector Response time at 3 K min⁻¹ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1: 20 K min⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 All others: 20 K min⁻¹ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Vibration resistance			
Shock (operational)	4.6.4.1		<p>No alarm or fault signal was given during the conditioning period or an additional 2 min.</p> <p>For specimen with a mass $\leq 4,75$ kg :</p> <p>Shock pulse type: Half sine Pulse duration : 6 ms Peak acceleration: $10X (100-20M) \text{ ms}^{-2}$ (M is specimen mass in Kg) Number of directions: 6 Pulses per direction: 3</p> <p><u>For resettable point heat detector</u> Response time at 3 K min^{-1} was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p><u>A1</u>: 20 K min^{-1} was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 <u>All others</u>: 20 K min^{-1} was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Impact (operational)	4.6.4.2		<p>No alarm or fault signal was given during the conditioning period or an additional 2 min.</p> <p>Conditioning: Impact energy: $1,9 \pm 0,1 \text{ J}$ Hammer velocity: $1,5 \pm 0,13 \text{ ms}^{-1}$ Number of impacts: 1</p> <p><u>For resettable point heat detector</u> Response time at 3 K min^{-1} was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p><u>A1</u>: 20 K min^{-1} was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 <u>All others</u>: 20 K min^{-1} was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Vibration, sinusoidal (operational)	4.6.4.3		<p>No fault signal was given during the conditioning</p> <p>Conditioning: Frequency range: 10 to 150 Hz Acceleration amplitude: $5 \text{ ms}^{-2} (\approx 0,5 \text{ g}_n)$ Number of axes : 3 Sweep rate: 1 octave min^{-1} Number of sweep cycles: 1 per axis</p> <p><u>For resettable point heat detector</u> Response time at 3 K min^{-1} was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p><u>A1</u>: 20 K min^{-1} was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 <u>All others</u>: 20 K min^{-1} was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6</p>

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Vibration, sinusoidal (endurance)	4.6.4.4	No fault signal was given on reconnection attributable to the endurance conditioning. Conditioning: Frequency range: 10 to 150 Hz Acceleration amplitude: 10 ms ⁻² (≈1,0 g _n) Number of axes : 3 Sweep rate: 1 octave min ⁻¹ Number of sweep cycles: 20 per axis <u>For resettable point heat detector</u> Response time at 3 K min ⁻¹ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6. <u>A1</u> : 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 <u>All others</u> : 20 K min ⁻¹ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6
Electrical stability EMC immunity (operational)	4.6.5	Compliance in EN 50130-4:2011 and No fault signal was given during the conditioning. <u>For resettable point heat detector</u> Response time at 3 K min ⁻¹ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6. <u>A1</u> : 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 <u>All others</u> : 20 K min ⁻¹ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6

Essential characteristics	Clauses in EN 54-7:2018	Regulatory classes	Performance
Operational reliability:		None	
Individual alarm indication	4.2.1		The visual indicator(s) are visible from a distance of 6 m in an ambient light intensity up to 500 lx.
Connection of ancillary devices	4.2.2		Open or short circuit failures of connection to ancillary device did not prevent the correct operation of the detector
Monitoring of detachable detectors	4.2.3		A fault condition is signaled when the detector is removed from the mounting base.
Manufacturer's adjustments	4.2.4		It is not possible to adjust the detector settings without the use of a special tool to access into the detector or use of a code to enabling entry into the panel programming software.
On site adjustment of response behavior	4.2.5		The mode(s) of operation are adjustable from the Control and Indicating Equipment by use of a loop communication protocol. Access to enable mode changes is by software control of the protocol communication.
Protection against the ingress of foreign bodies	4.2.6		The chamber is designed so that a sphere of diameter (1,3±0,05) mm cannot pass into the sensor chamber.
Response to slowly developing fires	4.2.7		The provision of "drift compensation" (e.g. to compensate for sensor drift due to the build-up of dirt in the detector), does not lead to a significant reduction in the detectors sensitivity to slowly developing fires.
Software controlled detectors (when provided)	4.2.8		The software documentation and the software design complies with the requirements of EN 54-7:2018.
Nominal activation conditions/sensitivity:		Threshold	

The certificate shall be reproduced in extenso
 – extracts only with written permission from DBI Certification A/S.

Repeatability	4.3.1	Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ Lower response value, $m_{\max}:m_{\min} \geq 0.05 \text{ dB m}^{-1}$
Directional dependence	4.3.2	Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ Lower response value, $m_{\max}:m_{\min} \geq 0.05 \text{ dB m}^{-1}$
Reproducibility	4.3.3	Ratio of response values $m_{\max}:\bar{m} \leq 1.33$ Ratio of the response values $\bar{m}:m_{\min} \leq 1.5$ Lower response value, $m_{\min} \geq 0.05 \text{ dB m}^{-1}$
Response delay (response time):		
Air movement	4.4.1	Ratio is > 0.0625 and < 1.60 and the point smoke detector did not emit a fault nor alarm signal during the test with aerosol-free air
Dazzling	4.4.2	The specimen did not emit neither an alarm nor a fault signal and Ratio of response thresholds $m_{\max}:m_{\min} \leq 1.6$
Tolerance to supply voltage:		
Variation in supply parameters	4.5	Ratio of response values $m_{\max}:m_{\min} < 1.6$ Lower response value, $m_{\min} \geq 0.05 \text{ dB m}^{-1}$
Performance parameters under fire conditions:		
Fire sensitivity	4.6	Evaluated as meeting the requirements of TF2 to TF5
Durability of nominal activation conditions/Sensitivity:		
temperature resistance		
Cold (operational)	4.7.1.1	The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Dry heat (operational)	4.7.1.2	The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Humidity resistance		
Damp heat, steady-state (operational)	4.7.2.1	The specimen did not emit neither an alarm nor a fault signal and ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Damp heat, steady-state (endurance)	4.7.2.2	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Corrosion resistance		
Sulphur dioxide (SO ₂) corrosion (endurance)	4.7.3	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Vibration resistance		
Shock (operational)	4.7.4.1	No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Impact (operational)	4.7.4.2	No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Vibration, sinusoidal (operational)	4.7.4.3	No fault signal given from the specimen during the conditioning and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Vibration, sinusoidal (endurance)	4.7.4.4	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Electrical stability EMC immunity (operational)	4.7.5	No alarm or fault signal given during the conditioning and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$
a) Electrostatic discharge (operational)		

The certificate shall be reproduced in extenso
 – extracts only with written permission from DBI Certification A/S.

b) Radiated electromagnetic fields (operational)			
c) Conducted disturbances(operational)			
d) Fast transient bursts (operational)			
e) Slow high energy voltage surge (operational)			

Essential characteristics	Clauses in EN 54-17:2005	Performance
Performance under fire conditions	5.2 1)	Pass
Operational reliability	4	Pass
Durability of operational reliability; temperature resistance	5.4, 5.5	Pass
Durability of operational reliability; vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability; humidity resistance	5.6, 5.7	Pass
Durability of operational reliability; corrosion resistance	5.8	Pass
Durability of operational reliability; electrical stability	5.3, 5.13	Pass
1) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices		

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
BRE	P101798 Issue: 1	23 October 2015
BRE	TE 295788-SW	15 October 2014
BRE	TE 295788-1	30 April 2015
BRE	TE P120605-1000 issue 1	14 December 2021

Annex 3

TECHNICAL BASIS

File Number	Title
SA5100-700 45681-210 SA5000-200	Build Standard Build Standard Build Standard

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.