

Certificate of constancy of performance

according to Regulation (EU) No. 305/2011



Certificate No.: 1008-CPR-MC 69262524 0001

Report No.: 28253125 001

Applicant: Apollo (Beijing) Fire Products Co., Ltd.
3rd Floor, No.5, Xinghai Road Beijing Economic-Technological
Development Area, Beijing 100176 China

Manufacturer: Apollo (Beijing) Fire Products Co., Ltd.
3rd Floor, No.5, Xinghai Road Beijing Economic-Technological
Development Area, Beijing 100176 China

Manufacturing plant: Apollo (Beijing) Fire Products Co., Ltd.
3rd Floor, No.5, Xinghai Road Beijing Economic-Technological
Development Area, Beijing 100176 China

Product: Conventional manual call point

Identification: SC2900-001 conventional manual call point
Intended use: Fire Safety

FPC Report No.: 28253126 001
Test Report No.: 50359980 001

**System of assessment
and verification:** 1

Tested according to: EN 54-11:2001 +A1: 2005

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performance described in Annex ZA of the above standard(s) under above system are applied and the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 2020-06-08 and it will remain valid until the test methods and/or factory production control requirements included in the standard, used to assess the performance of the declared characteristics, and the product, and the manufacturing conditions in the plant are unchanged. The manufacturing plant and factory production control system of the manufacturer is supervised regularly by the Certification Body.

Certification Body

Date of issue:
Budapest, 2020-06-08

Ferencne Schmidt

TÜV Rheinland InterCert Kft., Product Certification Body — H-1132 Budapest, Váci út 48/A-B, Hungary — www.tuv.com
Notified Body No. 1008

Validity of certificate can be checked on www.CERTIPEDIA.com

Essential characteristics	Performance	Harmonised technical specification
Operational performance	Pass	EN 54-11:2001 +A1: 2005
Function	Pass	
Test facility (operational)	Pass	
Reliability (endurance)	Pass	
Variation of supply parameters	Pass	
Dry heat (operational)	Pass	
Dry heat (endurance)	N/A	
Cold (operational)	Pass	
Damp heat, cyclic (operational)	Pass	
Damp heat, cyclic (endurance)	N/A	
Damp heat, steady state (endurance)	Pass	
SO ₂ corrosion (endurance)	Pass	
Shock (operational)	Pass	
Impact (operational)	Pass	
Vibration, sinusoidal (operational)	Pass	
Vibration, sinusoidal (endurance)	Pass	
Electromagnetic compatibility (EMC) (operational)	Pass	
Enclosure protection	N/A	

Certification Body

Date of issue:

Budapest, 2020-06-08

.....
Ferencne Schmidt