

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00035

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): Single Input/Output Unit and Dual Input/Output Unit
(refer to attached appendix for details and conditions)

Placed on the market under the name or trade mark of: Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR
United Kingdom

and produced in the manufacturing plant(s): Carrier Manufacturing Poland Sp. Zo.o. (SG-24159)
ul Kolejowa 24, 39-100 Ropczyce
Poland

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-25:2008+AC:2012
EN 54-18:2005+AC:2007

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00035** on **2014-12-14** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body 0905

Certification Manager: Dipl.-Ing. Roland Heine

Date Issue: 2023-11-29

Issue: 2

Signature:

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00035

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00035

The details and conditions of use for the **Single Input/Output Unit and Dual Input/Output Unit**, placed on the market under the name or trade mark of:

Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR
United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN 54-25:2008+AC:2012, EN 54-18:2005+AC:2007

Model	Manufacturing Location	Description
XPA-IN-14011-APO	SG-24159	Xpander Single Input/Output and
XPA-IN-14012-APO	SG-24159	Xpander Dual Input/Output Unit

Conditions of use:

Suitable for indoor applications.

General Notes:

1. Evaluated under Intertek project number 101938375 and G104828711.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.