

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00620

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): **XPander Wireless Remote Indicator Module**
(refer to attached appendix for details and conditions)
Placed on the market under the name or trade mark of: **Apollo Fire Detectors Limited**
36 Brookside Road, Havant, Hampshire, PO9 1JR
United Kingdom

and produced in the manufacturing plant(s): **Carrier Manufacturing Poland Sp. Zo.o. (SG-24159)**
ul Kolejowa 24, 39-100 Ropczyce, Poland

Intended use: **Fire Safety**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-25:2008+AC:2012

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00620** on **2017-02-01** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body

0905

Certification Manager: Dipl.-Ing. Roland Heine

Date Issue: 2023-10-16

Issue: 2

Signature:

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00620

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00620

The details and conditions of use for the XPander Wireless Remote Indicator Module, placed on the market under the name or trade mark of:

Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN 54-25:2008+AC:2012

Model	Manufacturing Location	Description
XPA-IN-14102-APO	SG-24159	XPander Wireless Remote Indicator Module

Batteries:

6 x 1.5 V AA Alkaline batteries as listed below

Panasonic

Panasonic Powerline (Size M, LR6)

Varta

Varta Industrial (4006, LR6)

Conditions of use:

Suitable for Indoor applications

General Notes:

1. Evaluated under Intertek project number 09042160a, 102821709LHD-001, G104828711
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.