

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1394:0120 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: APOLLO FIRE DETECTORS LTD36 Brookside Rd, Havant, Hampshire, P09 1JR United Kingdom
Contact: Chris Ellis 44 (0) 23 9249 2412 Fax 44 (0) 23 9249 2754
Email: chris.ellis@apollo-fire.com

DESIGN: Models 45681-524 and -527 Discovery Sounder Beacon Base; and Models 45681-525 and -526 XP95A Sounder Beacon Base. Units are a combination of a sounder with a beacon and a detector base. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 17-28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as smoke detector bases for use with listee's separately listed compatible smoke detectors for indoor use only. Not for evacuation notification use. Refer to listee's Installation Instruction Manual for details .

04-21-11 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division