



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-1394:0115
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	APOLLO FIRE DETECTORS LTD 36 Brookside Rd, Hampshire, MI, P09 1JR Contact: Barclay, Delia 44 (0) 23 9249 2412 Email: delia.barclay@apollo-fire.com
DESIGN:	XP95A Model 55000-750 isolator and 45681-211 isolator base. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as control unit accessories for use with separately listed compatible fire alarm control units. Model 55000-750 is only intended to be installed in the 4-wire redundant Style 7 of the Gamewell listed Models 620, 630, and 650 (CSFM Listing No. 7165-1288:144) fire alarm control units. Refer to listee's Installation Instruction Manual for details.
NOTES:	

Rev. 10-11-19 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/02/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division