

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	7300-1394:0108
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	APOLLO FIRE DETECTORS LTD 36 Brookside Rd, Hampshire, MI, P09 1JR Contact: Barclay, Delia 44 (0) 23 9249 2412 44 (0) 23 9249 2754 Email: delia.barclay@apollo-fire.com
DESIGN:	XP95A analog addressable signaling/contact monitoring modules. Model 55000-805 switch monitor module, Model 55000-806 priority switch monitor module, Model 55000-820 switch monitor input-output module, Model 55000-825 sounder control module, Model 55000-830 mini priority switch monitor module and Model 55000-831 mini switch monitor module. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	Electrical: 17 to 28 VDC, 5 to 9 V protocol
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as monitoring modules for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.
NOTES:	

*Rev. 06-20-03KK



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/02/2024 Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator Fire Engineering & Investigations Division