



TYPE APPROVAL CERTIFICATE

Certificate No:
TAA000006Y
Revision No:
3

This is to certify:

That the Fire Detector

with type designation(s)

**ORBIS Range of Conventional Heat, Optical Smoke and Multisensor Smoke Detector;
ORBIS Range of Intrinsically Safe (IS) Heat, Optical Smoke and Multisensor Smoke Detector**

Issued to

**Apollo Fire Detectors Limited
Havant, Hampshire, United Kingdom**

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Location classes:

Type	Temperature	Humidity	Vibration	EMC	Enclosure
ORBIS Range of Conventional Heat, Optical Smoke and Multisensor Smoke Detector;	C	B	B	B	B / IP44
ORBIS Range of Intrinsically Safe (IS) Heat, Optical Smoke and Multisensor Smoke Detector	C	B	B	B	B / IP44

Issued at **Høvik** on **2024-04-30**

for **DNV**

This Certificate is valid until **2026-12-31**.

DNV local station: **UK & Ireland CMC & VMC**

Approval Engineer: **Frode Nygård**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

Type approval of ORBIS and ORBIS Intrinsically Safe Ranges of Fire Detectors covers the following Part Numbers:

Part Number	Description
Orbis Bases	
ORB-MB-00001-MAR	TimeSaver Base
ORB-RB-40004-MAR	TimeSaver Relay Base
Orbis IS Bases	
ORB-MB-50018-APO	IS TimeSaver Base
ORB-BA-50008-APO	IS Base Adaptor (in conjunction with 45681-207 base)
Orbis Heat Detectors	
ORB-HT-41001-MAR	Category A1R Heat detector with SensAlert and FasTest
ORB-HT-41002-MAR	Category A2S Heat detector with SensAlert and FasTest
ORB-HT-41003-MAR	Category BR Heat detector with SensAlert and FasTest
ORB-HT-41004-MAR	Category BS Heat detector with SensAlert and FasTest
ORB-HT-41005-MAR	Category CR Heat detector with SensAlert and FasTest
ORB-HT-41006-MAR	Category CS Heat detector with SensAlert and FasTest
ORB-HT-41013-MAR	Category A1R Heat detector with SensAlert and FasTest and Flashing LED
ORB-HT-41014-MAR	Category A2S Heat detector with SensAlert and FasTest and Flashing LED
ORB-HT-41015-MAR	Category BR Heat detector with SensAlert and FasTest and Flashing LED
ORB-HT-41016-MAR	Category BS Heat detector with SensAlert and FasTest and Flashing LED
ORB-HT-41017-MAR	Category CR Heat detector with SensAlert and FasTest and Flashing LED
ORB-HT-41018-MAR	Category CS Heat detector with SensAlert and FasTest and Flashing LED
Orbis IS Heat Detectors	
ORB-HT-51145-APO	Category A1R Heat detector with SensAlert & FasTest
ORB-HT-51146-APO	Category A1R Heat detector with SensAlert, FasTest & Flashing LED
ORB-HT-51157-APO	Category A1S Heat detector with SensAlert & FasTest
ORB-HT-51158-APO	Category A1S Heat detector with SensAlert, FasTest & Flashing LED
ORB-HT-51147-APO	Category A2S Heat detector with SensAlert & FasTest
ORB-HT-51148-APO	Category A2S Heat detector with SensAlert, FasTest & Flashing LED
ORB-HT-51149-APO	Category BR Heat detector with SensAlert & FasTest
ORB-HT-51150-APO	Category BR Heat detector with SensAlert, FasTest & Flashing LED
ORB-HT-51151-APO	Category BS Heat detector with SensAlert & FasTest
ORB-HT-51152-APO	Category BS Heat detector with SensAlert, FasTest & Flashing LED
ORB-HT-51153-APO	Category CR Heat detector with SensAlert & FasTest
ORB-HT-51154-APO	Category CR Heat detector with SensAlert, FasTest & Flashing LED
ORB-HT-51155-APO	Category CS Heat detector with SensAlert & FasTest
ORB-HT-51156-APO	Category CS Heat detector with SensAlert, FasTest & Flashing LED
Orbis Optical Detectors	
ORB-OP-42001-MAR	Optical smoke detector with SensAlert, FasTest and DirtAlert
ORB-OP-42003-MAR	Optical smoke detector with SensAlert, FasTest and DirtAlert and Flashing LED
Orbis IS Optical Detectors	
ORB-OP-52027-APO	Optical smoke detector with SensAlert, FasTest and DirtAlert
ORB-OP-52028-APO	Optical smoke detector with Flashing LED, SensAlert, FasTest and DirtAlert
Multisensor Smoke Detectors	
ORB-OH-43001-MAR	Multisensor smoke detector with SensAlert, FasTest and DirtAlert
ORB-OH-43003-MAR	Multisensor smoke detector with SensAlert, FasTest and DirtAlert and Flashing LED

Part Number	Description
Multisensor Smoke Detectors	
ORB-OH-53027-APO	Multisensor smoke detector with SensAlert, FasTest and DirtAlert
ORB-OH-53028-APO	Multisensor smoke detector with Flashing LED, SensAlert, FasTest and DirtAlert

Application/Limitation

System application and location of detectors are to be in accordance with relevant parts of the Rules.

Ex installations to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

Ex-certification is not covered by this certificate and the following paragraph, which is for information only, is based on information received from the manufacturer, but not verified by DNV.

Information on Ex-Certification received from manufacturer – Not verified by DNV		
Equipment	Certified	Certificate No.
ORBIS IS Series Fire Detectors	Ex II 1 G Ex ia IIC T4 (-40°C ≤ Ta ≤ +60°C)/ T5 (-40°C ≤ Ta ≤ +40°C)	Baseefa 06ATEX0007X

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Type Approval documentation

Documentation	Documentation Reference Number
Product Guide	PP2147 2010/issue 4
Specification Data sheet	48000-15-issue 10, 48000-001-issue 12, 48000-13-issue 10
Circuit diagr.	100-OH-00003-issue 3, 100-OH-00004-issue 3, 100-HT-00001-issue 1, 100-HT-00002-issue 2
PCB Assy. drwg./Parts List	200-EA-00003-issue 4, 200-EA-00004, issue 4, 200-HT-00001-issue 2, 200-HT-00002-issue 3
Assy. drwg./Parts List	400-OH-00003-issue 6, 400-OH-00004-issue 5, 400-HT-00001-issue 2, 400-HT-00002-issue 2, 400-OP-00005-issue 6, 400-OP-00006-issue 5, 300-MA-00003, issue 6 38531-903-issue 6, 38531-909-issue 2, 38531-911-issue 3, 38531-902 Rev.8, 38531-969 Rev.4,
BRE Global Test Reports	P101167-1001-issue:1, dated 2015-08-14 P124660, dated 2023-04-04 TE-P105642-1001 Issue 1, dated 2022-09-02
Hursley EMC Services Test Report	18R110 ER Issue 1, dated 2018-03-26

Detector type	Test Reports	
	BRE Nos.	Apollo Nos.
Heat Detectors	21036, TE210363SW, 211499, 211499SW/A, 21499SW/B	1884.0
Optical Smoke Detectors	210362, 210362-SW, TE210362BSW	1840.0
Multisensor Smoke Detectors	210364, TE210364SW, 211500, E211500SW	1841.0

Detector type	EC – Type Examination Certificate
	Certification Number
ORBIS IS Series Fire Detectors	Baseefa06ATEX0007X

Type approval periodical assessment report for TAA000006Y, DNV Southampton on 2021-12-07.

Tests carried out

Applicable tests according to class guideline DNV-CG-0339, August 2021.

Performance tests according to:

- EN 54-5:2017 incl. A1:2018,
- EN 54-7:2018,
- EN 54-18:2005 incl. AC:2007.

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE