



Not to be distributed outside of FM Approvals and its affiliates except by Customer Member of the FM Global Group

APPROVAL REPORT

XP95A MODEL 55000-450 ADDRESSABLE HEAT DETECTOR (RE-EXAMINATION)

Prepared for:

**Apollo Fire Detectors Ltd.
36 Brookside Road, Havant
Hampshire, P09 1JR
United Kingdom**

Project ID: 3033993

Class: 3210

Date of Approval: 29 January 2010

Authorized by: J.E. Marquardt
J.E. Marquardt, Electrical Group Manager

Electrical Signaling

Electrical protective signaling systems are configurations of components used to produce alarm signals indicative of fire, smoke, sprinkler waterflow or other emergency and to produce supervisory signals indicative of conditions needing attention with respect to protection equipment or watch service. System configurations are classified according to where and how the signals are received. The categories are commonly designated as local, municipal, remote station, proprietary and central station. Auxiliary systems are either local or proprietary systems interconnected with a municipal system.

This category presents the major system component categories and the integrated system configurations. The selection of components to form a hybrid system should be made only by those skilled in system design. Also, the suitability of any system application should be judged on the basis of the hazard(s) being protected.

Alarm Signal Initiating Devices

Alarm signals are initiated either automatically or manually. Automatic detectors respond to changes in characteristic phenomena associated with fire or other emergency conditions.

Fire Detection, Heat-Actuated

Heat sensitive devices may be either "spot" or "line" type and operate at a fixed temperature or on a rapid increase in temperature (rate-of-rise). Some detectors combine the fixed and rate sensitive principles.

The spacing guides listed are indicative of each detector's relative sensitivity and, in each case, the spacing guide is the maximum recommended separation between detectors for smooth-ceiling installations. For a given temperature rating, a fixed-temperature detector which has a 30 ft (9 m) listing and one which has a 15 ft (5 m) listing will both respond at approximately the same time to a geometrically growing fire if each is installed at its listed spacing. FM Approved rate-of-rise detectors all have 30 ft (9 m) listed spacings, the maximum separation recommended by FM Approvals.

Installation of heat detectors at less than maximum spacing is necessary: to achieve earlier response; to compensate for ceiling obstructions such as beams and joists; and to compensate for ceiling heights greater than 15 ft (5 m). Proper location and use of heat detectors involves consideration of ceiling construction, the location of partitions, the maximum normal room temperature, heat produced by the occupancy, and whether detector function is to warn occupants or to automatically actuate protection equipment. Refer to Standard 72-1993 of the National Fire Protection Association and design specifications published by jurisdictional authorities, as appropriate.

XP95A Model 55000-450

XP95A Model 55000-450 Addressable Fixed heat detectors. RTI classification is STANDARD with a 15 x 15 ft (4.5 x 4.5 m) spacing. For use with Standard Detector Bases models 45681-210, 45681-225, 45681-250; Relay Base model 45681-242; Isolating Base model 45681-321. Must be used with FM Approved compatible fire alarm control panel. (See Local Protective Signaling for control panel listings).

Company Name:	Apollo Fire Detectors Ltd
Company Address:	36 Brookside Rd, Havant, Hampshire PO9 1JR, United Kingdom
Company Website:	http://www.apollo-fire.co.uk
Listing Country:	United Kingdom
Certification Type:	FM Approved