



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

Equipment Model Designations: Detectors

Model 55000-650 XP95A Series Smoke Detectors

Approval Guide Listing Category: 3230

Electrical Signaling Alarm Signal Initiating Devices Fire Detection, Smoke-Actuated Fire Detectors-Smoke

Apollo Fire Detectors Ltd
36 Brookside Rd
Havant
Hampshire, PO9 1JR
United Kingdom

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standards and other documents:

<i>Approval Standards</i>		<i>Other Standards</i>	
<i>Class Number</i>	<i>Date</i>	<i>Organization, Designation</i>	<i>Date</i>
3230	2020	none	


Original Approval Job Identification: 0Z8A2.AY

Approval Granted: 20 August 1996

Related Report: none

Subsequent Revisions: RR233231

To verify the availability of the Approved product, please refer to www.approvalguide.com



J.E. Marquedant
VP, Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA, 02062 USA

19 August 2022

Date



Member of the FM Global Group





Certificate of Compliance

☒ Electrical Signaling ☒ Alarm Signal Initiating Devices ☒ Fire Detection, Smoke-Actuated ☒ Fire Detectors-Smoke

55000-650 XP95A Series Smoke Detectors

Models	Description	Project ID
55000-650	Addressable Photoelectric Smoke Detector	0Z8A2.AY
Used with Base Models:		
45681-210	Standard Detector Bases	3057702
45681-225	Standard Detector Bases	3057702
45681-250	Standard Detector Bases	3057702
45681-284	Isolating Base	3057702

Must be used with FM Approved compatible fire alarm control panel. (See Local Protective Signaling for control panel listings).



Member of the FM Global Group