

Certificate of Product Approval

Certificate Number: 010bb

Issue: 09

Apollo Fire Detectors Limited

36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Commercial Detectors

SA5100-700

SA5100-760

(refer to Appendix for details)

Standards

EN 54-5:2017 + A1:2018

EN 54-7:2018

EN 54-17:2005

CEA 4021:2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

Z Major

Verifier

16 January 2024

Date of Issue

30 April 2015

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 010bb

Issue: 09

Apollo Fire Detectors Limited

Certified Product	Description	LPCB Ref.No.
SA5100-700	<p>Soteria Analogue Addressable Category A1R Optical Smoke/Heat Detector with Short Circuit Isolator (SA5000-200 and 45681-210 bases)</p> <p><i>Certified at the following settings:</i></p> <p>Mode 1: High sensitivity smoke detector with high heat enhancement</p> <p>Mode 2: Standard smoke sensitivity only</p> <p>Mode 3: Medium sensitivity smoke detector with medium heat enhancement</p> <p>Mode 4: Low sensitivity smoke detector with high heat enhancement</p> <p>Mode 5: Category A1R heat detector</p>	010bb/01
SA5100-760	<p>Soteria Analogue Addressable Category A1R Optical Smoke/Heat Detector with Short Circuit Isolator (Black body) (SA5000-200, 45681-210 and SA5000-204 bases)</p> <p><i>Certified at the following settings:</i></p> <p>Mode 1: High sensitivity smoke detector with high heat enhancement</p> <p>Mode 2: Standard smoke sensitivity only</p> <p>Mode 3: Medium sensitivity smoke detector with medium heat enhancement</p> <p>Mode 4: Low sensitivity smoke detector with high heat enhancement</p> <p>Mode 5: Category A1R heat detector</p>	010bb/02

Bases

SA5000-200	Addressable XPERT 8 Mounting Base
45681-210	XP95 Mounting Base
SA5000-204	XPERT 8 Base - Black

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for BRE Global Ltd

Z Major
Verifier

16 January 2024
Date of Issue

30 April 2015
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 010bb

Issue: 09

Apollo Fire Detectors Limited

Alternative Model No./Label

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
010bb/01	SA5100-700	SA5100-700LIM	Apollo Fire Detectors Limited	010bb/01
010bb/01	SA5100-700	SA5100-700LST	Labor Strauss Sicherungsanlagenbau GmbH	010bb/01
010bb/01	SA5100-700	SA5100-700AMP	Ampac Pty Ltd	010bb-(cl-1)
010bb/01	SA5100-700	EDE223-I	Schneider Electric Buildings AB	010bb-(cl-2)
010bb/01	SA5100-700	TEN-A8013	Shield Fire, Safety and Security Ltd	010bb-(cl-3)

Bases

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
010	SA5000-200	SA5000-200AMP	Ampac Pty Ltd	010bb-(cl-1)
010	SA5000-200	EBE200-N	Schneider Electric Buildings AB	010bb-(cl-2)
010	SA5000-200	TEN-A8030	Shield Fire, Safety and Security Ltd	010bb-(cl-3)
010	SA5000-200	SA5000-200	Labor Strauss Sicherungsanlagenbau GmbH	010bb
010	45681-210	45681-210AMP	Ampac Pty Ltd	010bb-(cl-1)
010	45681-210	45681-210	Labor Strauss Sicherungsanlagenbau GmbH	010bb

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for BRE Global Ltd

Z Major
Verifier

16 January 2024
Date of Issue

30 April 2015
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

