



EC Type Examination Certificate

Notified Body 2843

This is to certify that ABS ITALY S.R.L. did undertake the relevant type approval procedures for the type of equipment identified below which was found to be in compliance with the requirements of Marine Equipment Directive (MED) 2014/90/EU, subject to any conditions in the schedule attached hereto.

ITEM NUMBER: MED/3.51f

IMPLEMENTING REGULATIONS (EU) 2018/773

CERTIFICATE NUMBER: 11-792467-7-EC4

MANUFACTURER: Apollo Fire Detectors Ltd

MANUFACTURER'S LOCATION: Hampshire, UK

AUTHORIZED REPRESENTATIVE: Apollo Fire Detectors (Germany Office)

PRODUCT DESIGNATION: Fixed Fire detection and fire alarm systems components for control stations, service spaces, accommodation spaces, cabin balconies, machinery spaces and unattended machinery spaces
Manual Call Points

STANDARDS AND REGULATIONS: European Union Marine Equipment Directive 2014/90/EU referencing testing requirement of implementing regulation 2019/1397.
SOLAS 74 Reg. II-2/7; SOLAS 74 Reg. X/3; IMO Res. MSC.98(73)-(FSS Code)9;
IMO Res.MSC.36(63)-(1994 use Code) 7; IMO Res.MSC.97(73)-(2000 HSC Code) 7;
IMO Res. MSC.391(95)-(IGF Code) 11, IMO MSC.1/Circ.1242;
EN 54-11:2001 incl. A1 (2005);
IEC 60092-504 (2016), IEC 60533 (2015)

THIS CERTIFICATE IS ISSUED IN COMPLIANCE WITH CONFORMITY ASSESSMENT **MODULE B** OF THE REGULATIONS AND DIRECTIVES LISTED ABOVE.

ISSUE DATE: 30-oct-2020

EXPIRATION DATE: 31-aug-2022

ELECTRONICALLY
SIGNED BY: E. Brina

This certificate will not be valid if the manufacturer makes any changes or modifications to the approved type of equipment, which have not been notified to, and agreed with the notified body named on this certificate.

Should the specified regulations or standards be amended during the period of validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on the market and on board vessels to which the amended regulations or standards apply.

The "Mark of Conformity" may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-control phase module (D, E, or F) of ANNEX B of the Directive is fully complied with and controlled by a written inspection agreement with a notified body.

The attached document schedule forms part of this Certificate.

This certificate remains valid unless suspended, expired or withdrawn, provided the conditions in the attached schedule are complied with.

Entry Date: 30-oct-2020

**Name of Equipment
Manufacturer:**

Apollo Fire Detectors Ltd
36 Brookside Road
Havant, Hampshire
PO9 1JR United Kingdom
Tel: +44 (0) 2392442732
Email: francesca.stott@apollo-fire.com
Website: www.apollo-fire.com

Manufacturer site: N/A

Authorized representative:

Apollo Fire Detectors (Germany Office)
Gesellschaft für Meldetechnologie mbH
Am Anger 31
33332 Gütersloh
Germany
Tel. +49 5241 33060

Equipment/Component:

Fixed Fire detection and fire alarm systems components for control stations, service spaces, accommodation spaces, cabin balconies, machinery spaces and unattended machinery spaces:
- Manual Call Points

Model:

58100-970MAR Red Manual Call Point
58100-971MAR Red Manual Call Point with isolator
58100-975MAR Waterproof Manual Call Point
58100-976MAR Waterproof Manual Call Point with isolator
55100-940 Red Manual Call Point

Description:

Analogue addressable call points for marine and offshore applications in process, machinery and accommodation spaces.

Intended Service:

Analogue addressable call points for marine and offshore applications in process, machinery and accommodation spaces.

Ratings:

Apollo Analogue Addressable Call Points

Nominal voltage 17 to 28V DC
Operating temperature -20C to 60C, -30C to 70C or -40C to 70C dependent on model
Quiescent current 100 microA to 400microA dependent on model

Apollo Manual Call Points
Nominal voltage: 14 to 22V DC;
Operating temperature: -20C to 60C;
Quiescent current: 230 to 340 microA;
Alarm current: 10 to 60 mA

Standards:

European Union Marine Equipment Directive 2014/90/EU referencing testing requirement of implementing regulation 2019/1397

SOLAS 74 Reg. II-2/7; SOLAS 74 Reg. X/3; IMO Res. MSC.98(73)-(FSS Code)9;
 IMO Res.MSC.36(63)-(1994 use Code) 7; IMO Res.MSC.97(73)-(2000 HSC Code) 7;
 IMO Res. MSC.391(95)-(IGF Code) 11,
 IMO MSC.1/Circ.1242;
 EN 54-11:2001 incl. A1 (2005);
 IEC 60092-504 (2016), IEC 60533 (2015)

Service Restrictions/Limitations:

Ex certification is not covered by this certificate. Application or installation in hazardous area to be approved in each case according to Ex certification / Special condition for safe use listed in valid Ex certificate issued by a notified/recognized Certification Body.

Comments:

Should the specified regulations or standards be amended during the validity of this certificate, the products are to be re-approved prior to being placed on board vessels to which the amended regulations or standards apply.

This certificate will not be valid if the manufacturer makes any changes or modifications to the approved equipment, which have not been notified to, and agreed with the Notified Body named on this certificate.

A Manufacturer's Declaration of Conformity shall be compiled and distributed in line with the requirements of Directive 2014/90/EU Article 16.

The Mark of Conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-control phase module (D, E, or F) of ANNEX II of the Directive is fully complied with and controlled by a written inspection agreement with a notified body.

Revisions:

Certificate N°. 11-792467-7-EC4, replaces Certificate N°. 11-LD792467-6-EC4 Dated: 01-sep-2020

Drawing Schedule:

Drawing No	Description
16-LD1536864-PDA	PRODUCT DESIGN ASSESSMENT