

This is to certify that ABS ITALY S.R.L. did undertake the relevant type approval procedures for the type of equipment identified below which was found to be in compliance with the requirements of Marine Equipment Directive (MED) 2014/90/EU, subject to any conditions in the schedule attached hereto.

ITEM NUMBER:	MED/3.51d
IMPLEMENTING REGULATIONS	(EU) 2018/773
CERTIFICATE NUMBER:	11-792467-7-EC11
MANUFACTURER:	Apollo Fire Detectors Ltd
MANUFACTURER'S LOCATION:	Hampshire, UK
AUTHORIZED REPRESENTATIVE:	Apollo Fire Detectors (Germany Office)
PRODUCT DESIGNATION:	Fixed Fire detection and fire alarm systems components for control stations, service spaces, accommodation spaces, cabin balconies, machinery spaces and unattended machinery spaces <u>Smoke detectors - Point detectors</u>
STANDARDS AND REGULATIONS:	
	European Union Marine Equipment Directive 2014/90/EU referencing testing requirement of implementing regulation 2019/1397. SOLAS 74 Reg. II-2/7; SOLAS 74 Reg. X/3; IMO Res. MSC.98(73)-(FSS Code)9; IMO Res.MSC.36(63)-(1994 use Code) 7; IMO Res.MSC.97(73)-(2000 HSC Code) 7; IMO Res. MSC.391(95)-(IGF Code) 11, IMO MSC.1/Circ.1242; EN 54-7(2000) + A1(2002) + A2(2006); IEC 60092-504 (2016), IEC 60533 (2015)
This Certificate is issued in c	OMPLIANCE WITH CONFORMITY ASSESSMENT MODULE B OF THE REGULATIONS AND DIRECTIVES LISTED ABOVE.
ISSUE DATE: 30-oct-20	20 Expiration Date: 31-aug-2022
ELECTRONICALLY SIGNED BY: E. Bri	ina U

This certificate will not be valid if the manufacturer makes any changes or modifications to the approved type of equipment, which have not been notified to, and agreed with the notified body named on this certificate.

Should the specified regulations or standards be amended during the period of validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on the market and on board vessels to which the amended regulations or standards apply.

The "Mark of Conformity" may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-control phase module (D, E, or F) of ANNEX B of the Directive is fully complied with and controlled by a written inspection agreement with a notified body.

The attached document schedule forms part of this Certificate.

This certificate remains valid unless suspended, expired or withdrawn, provided the conditions in the attached schedule are complied with.

ABS ITALY SRL - Attachment to Cei	<i>rtificate No.</i> 11-792467-7-EC11 Page 2 of
Entry Date:	30-oct-2020
<i>Name of Equipment Manufacturer:</i>	Apollo Fire Detectors Ltd 36 Brookside Road Havant, Hampshire PO9 1JR United Kingdom Tel: +44 (0) 2392442732 Email: francesca.stott@apollo-fire.com Website: www.apollo-fire.com
Manufacturer site:	N/A
Authorized representative:	Apollo Fire Detectors (Germany Office) Gesellschaft für Meldetechnologie mbH Am Anger 31 33332 Gütersloh Germany Tel. +49 5241 33060
Equipment/Component:	Fixed Fire detection and fire alarm systems components control stations, service spaces, accommodation space cabin balconies, machinery spaces and unattended machine spaces: - Smoke detectors
Model:	Apollo Orbis conventional range of Smoke detectors
Description:	The Orbis IS range detectors are microprocessor-bas conventional fire detection units with standard IS (time-savir electronic-free bases comprising: ORB-OH-53027-APO Multisensor Smoke Detector with SensAlert/FasTest/DirtAlert ORB-OP-52027-APO Optical Smoke Detector with Sensalert/FasTest/DirtAlert ORB-OP-52028-APO Optical Smoke Detector with Flashing LED/SensAlert/FasTest/DirtAlert ORB-OH-53028-APO Multisensor Smoke Detector with Flashing LED/SensAlert/FasTest/DirtAlert
T	T

ABS ITALY SRL - Attachment to Certificate No. 11-792467-7-EC11

Intended Service:	Conventional
	applications i

Ratings:

Standards:

Service Restrictions/Limitations:

Comments:

Revisions:

Conventional fire detection systems for marine and offshore applications in machinery and accommodation spaces.

Nominal voltage: 14 to 24V DC (non-polarised); Operating temperature: -40 °C to 70 °C;

European Union Marine Equipment Directive 2014/90/EU referencing testing requirement of implementing regulation 2019/1397

SOLAS 74 Reg. II-2/7; SOLAS 74 Reg. X/3; IMO Res. MSC.98(73)-(FSS Code)9; IMO Res.MSC.36(63)-(1994 use Code) 7; IMO Res.MSC.97(73)-(2000 HSC Code) 7; IMO Res. MSC.391(95)-(IGF Code) 11, IMO MSC.1/Circ.1242; EN 54-7(2000) + A1(2002) + A2(2006); IEC 60092-504 (2016), IEC 60533 (2015)

Ex certification is not covered by this certificate. Application or installation in hazardous area to be approved in each case according to Ex certification / Special condition for safe use listed in valid Ex certificate issued by a notified/recognized Certification Body.

Should the specified regulations or standards be amended during the validity of this certificate, the products are to be re-approved prior to being placed on board vessels to which the amended regulations or standards apply.

This certificate will not be valid if the manufacturer makes any changes or modifications to the approved equipment, which have not been notified to, and agreed with the Notified Body named on this certificate.

A Manufacturer's Declaration of Conformity shall be compiled and distributed in line with the requirements of Directive 2014/90/EU Article 16.

The Mark of Conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the productioncontrol phase module (D, E, or F) of ANNEX II of the Directive is fully complied with and controlled by a written inspection agreement with a notified body.

Certificate N°. 11-792467-7-EC11, replaces Certificate N°. 11-LD792467-6-EC11 Dated: 30-aug-2019

Drawing Schedule:

Drawing No 20-1966612-PDA

Description PRODUCT DESIGN ASSESSMENT