



## **TEST CERTIFICATE No. 8314313422**

In accordance with Clause 12 of the Standards Law 1953

### **Details of order**

Name of customer : APOLLO Fire Detectors Limited  
Address : 36 Brookside Road, Havant, Hampshire England PO9 1JR  
Date of order : 12/03/2003  
The specimen was taken by a representative of SII.

### **Test of**

DISCOVERY Heat detectors type 58000-450 manufactured by APOLLO U.K. (UL LISTED).

### **Nature of test**

Testing the compliance of the samples with the Israeli Standard SI 1220 part 4  
"FIRE PROTECTIVE SIGNALING SYSTEMS": Heat Detector, November 1988:

This report contains 2 pages and may be used only in full.

This report refers to the test sample only and does not apply to other samples of the same product.

This document alone is not sufficient for the release of goods from customs.

### **General:**

At the request of the customer, submitted for tests Heat detectors type 58000-450 APO manufactured by Apollo U.K.

The detectors were tested with the analog fire alarm control panel type "FDX-5000" manufactured by Firesense Ltd Israel.

### **Conclusions:**

The detectors which have been tested comply with the requirements of the Israeli standard 1220 part 4.

The original test certificate was signed by:

Signed by: Albert Azoulay

Position: Head, Alarm System Section

I confirm that this is a true translation of the Hebrew original. Only the original test certificate is authentic.